WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

**PRINT OR TYPE ONLY**
**DO NOT WRITE ON BACK**

STATE OF NEVADA
# DIVISION OF WATER RESOURCES
# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 87589
Permit No.
Basin 162

NOTICE OF INTENT NO. 24451

1. OWNER BUILTWELL
MAILING ADDRESS 980 LUPIN
PAHRUMP, NV 89048

ADDRESS AT WELL LOCATION 980 LUPIN

2. LOCATION SW 1/4 NW 1/4 Sec. 28 T 20S N/S R 53 E NYE County
PERMIT NO. _____ Issued by Water Resources | 39-062-06 Parcel No. | CALVADA VALLEY UNIT8B Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| CLAY | | 0 | 70 | 70 |
| CALICHE | WB | 70 | 95 | 25 |
| CLAY | | 95 | 110 | 15 |
| CALICHE | WB | 110 | 140 | 30 |

DCNR/DWR
RECEIVED
JAN 24 2003
LAS VEGAS OFFICE

Date started 1/13/2003, 19__
Date completed 1/16/2003, 19__

7. WELL TEST DATA

TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| | | |

8. WELL CONSTRUCTION

Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

| | From | To |
|---|---|---|
| 10.25 Inches | 0 Feet | 140 Feet |
| Inches | Feet | Feet |
| Inches | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 6 | 3.63 | 250 | 0 | 140 |

**Perforations:**
Type perforation SAWCUT
Size perforation 1/8 X 3
From 100 feet to 140 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 140 feet

9. WATER LEVEL
Static water level 55 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name GREAT BASIN DRILLING CO. OF NEVADA, INC.
Contractor
Address P.O. BOX 4220
Contractor
PAHRUMP,NV. 89048

Nevada contractor's license number issued by the State Contractor's Board 47333

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642

Signed Ron Tosh
By driller performing actual drilling on-site or contractor

Date 1/22/03

USE ADDITIONAL SHEETS IF NECESSARY