WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 87605
Permit No.
Basin 212

NOTICE OF INTENT NO. 24304

1. OWNER: CLARK COUNTY SCHOOL DISTRICT
MAILING ADDRESS: 4828 PEARL STREET
LAS VEGAS, NV 89121

ADDRESS AT WELL LOCATION: 1776 E. OGDEN AVE.
LAS VEGAS, NV (HOLLINGWORTH ES)

2. LOCATION: SE ¼ NE ¼ Sec. 35 T. 20 N/S R. 61 E. CLARK County
PERMIT NO. DW1130 (Issued by Water Resources) 139-35-710-001 (Parcel No.) (Subdivision Name)

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE Dewater
☐ Domestic ☐ Irrigation ☐ Test
☒ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
~~Abandon 5-dewater wells~~				
~~Well depth 30' each~~				
~~Tried to pull casings, casings cemented in. Wells abandon with casings in place.~~				
~~Filled with 2 yards of 9 sack sand and cement grout each.~~				

RECEIVED
FEB 06 2003
LAS VEGAS OFFICE

Date started 12/20/02, 20
Date completed 1/11/03, 20

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 30' Feet Depth Cased 30' Feet

HOLE DIAMETER (BIT SIZE)

	From	To
24" Inches	0 Feet	30 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
14	36.71	1.250	0	30

Perforations:
Type perforation: Machine Perforate
Size perforation: 1/4" x 2 1/2" x 3 rows @ 13
From 10 feet to 30 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☐ No
Depth of Seal
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☐ Yes ☐ No
From 0 feet to 30 feet

9. WATER LEVEL
Static water level 11' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name: ALLEN DRILLING INC. (Contractor)
Address: 4015 WEST TOMPKINS (Contractor)
LAS VEGAS, NV 89103
Nevada contractor's license number issued by the State Contractor's Board: 18917
Nevada driller's license number issued by the Division of Water Resources, the on-site driller: 1301
Signed: Fred B. Allen III
By driller performing actual drilling on site or contractor
Date 2/3/03

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627