

Log No. 87643
 Permit No. 58714
 Basis 0a3

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 20282

1. OWNER Midas Water Colop ADDRESS AT WELL LOCATION Midas Canyon
 MAILING ADDRESS 115 Wood Drive
Fallon Nev

2. LOCATION SE 1/4 NE 1/4 Sec. 20 T. 39 N/S R 46 E Humboldt County
 PERMIT NO. Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Clayey Sand		0	8	8
Clay & Boulders		8	18	10
Red Clay		18	24	6
Greenish Clay		24	26	2
Clay and Grv	X	26	83	57
Clay with Bolders	X	83	110	27
Green rock		110	150	40
Same/fractured	X	150	163	13
Green rock with occasional small				
FRAC ZONE	X	163	370	207
Green rock		370	500	130

8. WELL CONSTRUCTION
 Depth Drilled 500 Feet Depth Cased 360 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 3/4 Inches To 5 5/8 Feet
 From 8 3/4 Inches To 500 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 7/8</u>	<u>12.9</u>	<u>.188</u>	<u>41</u>	<u>360</u>

Perforations:
 Type perforation Machine slot
 Size perforation .0050
 From 85 feet to 110 feet
 From 280 feet to 360 feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal 55
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 37 feet below land surface
 Artesian flow _____ G.P.M. P.S.I.
 Water temperature 52 °F Quality Un-Tested

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Welco Contractor
 Address Box 888 Contractor
 Nevada contractor's license number issued by the State Contractor's Board 11752
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 772
 Signed W. B. Wille
 By driller performing actual drilling on site or contractor
 Date Dec-7-92

Date started July 21 1992
 Date completed Nov-31 1992

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift


G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>35</u>	<u>300</u>	<u>12</u>

RECEIVED
 JAN - 7 1993
 STATE ENGINEERS OFFICE

COPY FILED 05/01/95

WHITE-DIVISION OF WATER RESOURCES
CANARY-CLIENT'S COPY
PINK-WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES



Log No. 49078
Permit No. 884
Basin 4-063

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 20282

1. OWNER WIDAS WATER COLOP ADDRESS AT WELL LOCATION WIDAS CANYON
 MAILING ADDRESS 1195 Wood Drive
FALLEN MEU

2. LOCATION SE 1/4 NE 1/4 Sec 20 T 39 N/S R 46 E Humboldt ETKO County
 PERMIT NO. Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Clayey Sand		0	8	8
Clay & Boulders		8	18	10
Red Clay		18	24	6
Greenish Clay		24	26	2
Clay and Grul	X	26	83	57
Clay with Boulders	X	83	110	27
Green rock		110	150	40
Sand fractured	X	150	163	13
Green rock with				
OCCASIONAL SMALL				
FRAC ZONE	X	163	370	207
Green rock		370	500	130

8. WELL CONSTRUCTION
 Depth Drilled 500 Feet Depth Cased 360 Feet

HOLE DIAMETER (BIT SIZE)
 From To
10 3/4 Inches 5 Feet 55 Feet
8 3/4 Inches 55 Feet 500 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>12.9</u>	<u>.188</u>	<u>4</u>	<u>360</u>

Perforations:
 Type perforation MACHINE SLIT
 Size perforation .0050
 From 55 feet to 110 feet
 From 280 feet to 360 feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout

Depth of Seal 55

Placement Method: Pumped Poured

Gravel Packed: Yes No

From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 37 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature 52 °F Quality GOOD TASTED

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name WELSCO Contractor
 Address Box 888 Contractor

Nevada contractor's license number issued by the State Contractor's Board 11952
 Nevada driller's license number issued by the Division of Water Resources, the on site driller 772

Signed WELSCO
 By driller performing actual drilling on site or contractor

Date Dec - 7 - 92

Date started July 21, 1992
 Date completed Nov - 31, 1992

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>35</u>	<u>300</u>	<u>12</u>