

OFFICE USE ONLY
 Log No. 87650
 Permit No. _____
 Basin D91

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 50417

1. OWNER ALAN GLEN ADDRESS AT WELL LOCATION "Guest House Well"
 MAILING ADDRESS P.O. BOX 8460 860 Bridge Street
Incline Village, Nevada 89452 Verdi, Nevada 89439
 2. LOCATION NW 1/4 NE 1/4 Sec. 18 T. 19N N/S R. 18 E Washoe County
 PERMIT NO. 038-821-07 Verdi area
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	1	1
Brown clay with gravels		1	4	3
Boulder		4	6	2
Brown clay, gravel & sand		6	14	8
Granite boulder		14	16	2
Gravels, sand & boulder		16	55	39
Brown sandy clays		55	70	15
Gray sandy clays		70	88	18
Dark brown sandy clays		88	95	7
Soft zone	X	95	104	9
Dark brown sandy clays		104	110	6
Gray sandy clays		110	124	14
Soft zone	X	124	127	3
Gray sandy clays		127	139	12
Soft zone	X	139	144	5
Gray sandy clays		144	153	9
Gray volcanic rock		153	161	8
Gray sandy clay streak		161	163	2
Gray volcanic rock with streaks of clay		163	209	46
Soft zone	X	209	214	5
Gray volcanic rock		214	254	40
Gray clay		254	261	7
Gray volcanic rock		261	266	5
Hard gray volcanic rock		266	270	4

8. WELL CONSTRUCTION
 Depth Drilled 270 Feet Depth Cased 270 Feet
 HOLE DIAMETER (BIT SIZE)
 From 9 7/8 Inches To 270 Feet
 _____ Inches _____ Feet
 _____ Inches _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>		<u>.188</u>	<u>0</u>	<u>270</u>

Perforations:
 Type perforation factory sawed slot
 Size perforation 3/32 x 3 x 5 around
 From 105 feet to 165 feet
 From 205 feet to 225 feet
 From 245 feet to 265 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 100 feet Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 100 feet to 270 feet

9. WATER LEVEL
 Static water level 39.3 feet below land surface
 Artesian flow _____ G.P.M. 20+ P.S.I.
 Water temperature cold °F Quality clear

Date started August 21, 2002, 20____
 Date completed August 28, 2002, 20____

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>20+</u>		

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name WAYNE DRILLING, INC. Contractor
 Address P.O. BOX 12370 Contractor
RENO, NEVADA 89510
 Nevada contractor's license number issued by the State Contractor's Board 0022549
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date September 3, 2002

KENNY C. GUINN
Governor

STATE OF NEVADA

R. MICHAEL TURNIPSEED, P.E.
Director



HUGH RICCI, P.E.
State Engineer

DEPARTMENT OF CONSERVATION AND NATURAL RESOURCES
DIVISION OF WATER RESOURCES

123 W. Nye Lane, Suite 246
Carson City, Nevada 89706-0818
(775) 687-4380 • Fax (775) 687-6972
<http://ndwr.state.nv.us>

August 16, 2002

Alan Glen
860 Bridge St.
Verdi, NV 89439

RE: Two domestic wells on one parcel APN 038-821-07.

Dear Mr. Glen:

This letter will give written authorization for the installation of a second domestic well on one parcel being described as Washoe County APN 038-821-07, located at 860 Bridge Street in Verdi Nevada. This authorization is given with the understanding that the proposed well will be for "DOMESTIC USE" ONLY. Any other use other than domestic use as defined under NRS § 534.013 will require a water rights permit from this office.

If you have any questions, please contact this office at (775) 687-3861.

Sincerely,

A handwritten signature in black ink, appearing to read "T. Hunt".

Tim Hunt
Well Supervisor

TH/hf

cc: Wayne Drilling, Inc.
Washoe County District Health