

OFFICE USE ONLY  
 Log No. 87653  
 Permit No. \_\_\_\_\_  
 Basin 10.3

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 50355

1. OWNER Amy Furgeson ADDRESS AT WELL LOCATION 10100 Coleman Ln Stagecoach, NV 89429  
 MAILING ADDRESS 10100 Coleman Ln Stagecoach, NV 89429  
 2. LOCATION SE 1/4 SE 1/4 Sec 4 T 17 N 23 E County Lyon  
 PERMIT NO. 19-811-02 Parcel No. \_\_\_\_\_ Subdivision Name Hughes

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sandy Silt		0	12	
Large Sand and Silt		12	35	
Gravel Silt Some		35	95	
Br. Clay		95	97	
Cobbles Silt Br. Clay		97	120	
Cobbles Gravel Br. Clay		120	168	
Some Sand				
Cobbles Sand Gravel		168	178	
Cobbles Brown Clay		178	185	
Cobbles Sand + Gravel		185	198	
Cobbles + Br. Clay		198	200	

8. WELL CONSTRUCTION  
 Depth Drilled 200' Feet Depth Cased 200' Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 10 5/8 Inches To 200 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet  
 CASING SCHEDULE  

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>		<u>.188</u>	<u>+1</u>	<u>160</u>

 Perforations:  
 Type perforation Mill Slot  
 Size perforation 3/32  
 From 160 feet to 200 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  
 Neat Cement  
 Cement Grout  
 Concrete Grout  
 Placement Method:  Pumped  
 Poured  
 Gravel Packed:  Yes  No  
 From 50 feet to 200 feet

RECEIVED  
 02 DEC 20 AM 11:31  
 STATE ENGINEERS OFFICE

Date started 11-29, 2002  
 Date completed 12-2, 2002

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift			
<u>Air Lift</u>	<u>20-25</u>		<u>3 hours</u>

9. WATER LEVEL  
 Static water level 9.6 feet below land surface  
 Artesian flow N/A G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature Cold °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name \_\_\_\_\_  
Nevada Pump & Drilling  
 Address P.O. Box 2227 Dayton, NV 89403  
 Nevada contractor's license number issued by the State Contractor's Board 046357  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1790  
 Signed [Signature]  
 By driller performing actual drilling on site or contractor  
 Date 12-14-02