WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 87663
Permit No.
Basin 122

NOTICE OF INTENT NO. 46727

1. OWNER BLM Carson City Field office
MAILING ADDRESS 5665 Morgan Mill Rd. Carson City, NV 89701

ADDRESS AT WELL LOCATION Gabbs Solid waste site 1/4 Mile west of Gabbs' GMW-3

2. LOCATION NW 1/4 SW 1/4 Sec. 33 T. 12 N/S R. 36 E Nye County
PERMIT NO. Mo 1249 Issued by Water Resources | Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other H.S.A.

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Dry fine grain sand	–	0	5'	5'
Moist silty sand w/clay	8.3	5'	11'	6'
Sandy silt some clay	8.3	11'	16'	5'
Clayey sand, some gravel	8.3	16'	17'	1'
Silty clay	8.3	17'	20'	3'

GMW-3

RECEIVED 02 JUL 22 AM 11:37 STATE ENGINEERS OFFICE

Date started 5-21-02
Date completed 5-21-02

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 20 Feet Depth Cased 20 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
8 1/2 Inches	0 Feet	20 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2"		5.40	+2'	10'

Perforations:
Type perforation Long Year Factory slot
Size perforation .020
From 10' feet to 20' feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 8
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout (3'-8' Bentonite chips)
Gravel Packed: ☒ Yes ☐ No
From 20 feet to 8' feet

9. WATER LEVEL
Static water level 8.3 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature 85° °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Haz-Tech Drilling Inc. Contractor
Address 475 N. Linder Rd. Meridian, ID 83680 Contractor
Nevada contractor's license number issued by the State Contractor's Board 0038018
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-1803
Signed [signature] By driller performing actual drilling on site or contractor
Date 5-21-02

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627