WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 8766A
Permit No.
Basin 122

NOTICE OF INTENT NO. 46727

1. OWNER BLM, Carson City Field Office
MAILING ADDRESS 5665 Morgan Mill Road
Carson City NV, 89701

ADDRESS AT WELL LOCATION Gabbs Solid Waste Site. 1/4 West of Gabbs, GMW-2

2. LOCATION NW 1/4 SW 1/4 Sec. 33 T. 12 N/S R. 36 E. NYE County

PERMIT NO. M/O 1249 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other H.S.A.

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Silty clay	0	0'	2½'	2½'
Sandy silt w/clay	4'	2½'	11'	8.5'
Silty clay	4'	11'	11½'	½'
Sand small gravel - B-6 clay	4'	11½'	16'	4.5'
Very Fine sand	2½'	16'	18'	2'
V-Fine sand w/clay.	2½'	18'	20'	2'

GMW-2

RECEIVED 02 JUL 22 AM 11:37 STATE ENGINEERS OFFICE

Date started 5-20-02
Date completed 5-20-02

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 20 Feet Depth Cased 20 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From Feet	To Feet
8½	0	20'

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2"		5.40	+2	5'
2"		5.40	15'	20'

Perforations:
Type perforation Factory slot
Size perforation .020
From 5 feet to 15' feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 2½
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 20' feet to 4' feet

9. WATER LEVEL
Static water level 2.5' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature <85° °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Haz-Tech Drilling Inc. (Contractor)
Address 475 N. Linder Road Meridian (Contractor)
ID 83680
Nevada contractor's license number issued by the State Contractor's Board 0038018
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-1803
Signed Mike Cor (By driller performing actual drilling on site or contractor)
Date 5-20-02

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627