WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 87669
Permit No.
Basin 101

NOTICE OF INTENT NO. 50586

1. OWNER Ron Evans
MAILING ADDRESS 2995 Alcorn Road
Fallon, NV 89406

ADDRESS AT WELL LOCATION 1415 Golden Parkway,
Fallon, NV 89406

2. LOCATION SW 1/4 SW 1/4 Sec. 19 T 19N N/S R 28E E Churchill County
PERMIT NO. (Issued by Water Resources) 008-312-71 (Parcel No.) Subdivision Name

3. **WORK PERFORMED**
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. **PROPOSED USE**
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. **WELL TYPE**
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. **LITHOLOGIC LOG**

Material	Water Strata	From	To	Thickness
Brown Sand		0	8	8
Brown Clay		8	15	7
Brown Sand		15	30	15
Brown Clay		30	32	2
Gray Clay		32	40	8
Black Sand		40	44	4
Gray Clay		44	56	12
Black Clay		56	60	4
Gray Sand		60	68	8
Gray Clay		68	80	12
Brownish Sand		80	90	10
Brown Sand		90	100	10
Brown Clay		100	101	1
Brown Sand	XX	101	107	6

Date started 09/30/2002, 19__
Date completed 09/30/2002, 19__

7. **WELL TEST DATA**
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20		1hr

8. **WELL CONSTRUCTION**
Depth Drilled 107 Feet Depth Cased 107 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10	Inches	0	Feet	107	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	0	10
6 PVC	3.92	.258	10	107

Perforations:
Type perforation Saw CUt
Size perforation 1/8
From 101 feet to 104 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 100
Placement Method: [X] Pumped [ ] Poured

Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 100 feet to 107 feet

9. **WATER LEVEL**
Static water level 22 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cool °F Quality unknown

10. **DRILLER'S CERTIFICATION**
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Parsons Drilling, Inc. (Contractor)
Address P.O. Box 1265 (Contractor)
Fallon Nv. 89407-1265
Nevada contractor's license number issued by the State Contractor's Board 29064
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2212
Signed [signature] (By driller performing actual drilling on-site or contractor)
Date 10/18/2002

USE ADDITIONAL SHEETS IF NECESSARY