WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 87685
Permit No.
Basin 065

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 51089

1. OWNER Newmont Mining
MAILING ADDRESS P.O. Box 388
ADDRESS AT WELL LOCATION 5440 Bench

2. LOCATION SE ¼ NE ¼ Sec. 11 T 34 N/S R 42 E Humboldt County
PERMIT NO. (Issued by Water Resources) Parcel No. Subdivision Name

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☐ Irrigation ☐ Test ☑
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☐
Other ☐ RC ☑

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Fill		0	10	10
Sandstone		10	100	90
Conglomerate		100	215	115
quartzite		215	1300	1085

Note
Hydrologist changed mind and decided to abandon borehole rather than completel as monitor well

Hole was abandoned from 1300'-578' with abandonite bags 578'-10' was abandoned with 67 bags of 3/8" hole plug 10' cement seal set at surface.

Date started 8-22, 1902
Date completed 8-29, 1902

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
	75	1	1hr

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 10" inches Total depth 1300' feet
6" inches
5 5/8" inches
Casing record 6 5/8"
Weight per foot 12.9# Thickness .188

Diameter	From	To
6 5/8" inches	0 feet	20 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type Cement
Depth of seal 20' feet
Gravel packed: Yes ☐ No ☐
Gravel packed from ..... feet to ..... feet

Perforations:
Type perforation
Size perforation
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Dewatered ~~Static~~ water level 578.4 feet below land surface
Flow 75 G.P.M. ..... P.S.I.
Water temperature 90 °F Quality Poor

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Elkhead Drilling (Contractor)
Address 605 Union Pacific Way (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 0019378
Nevada contractor's driller's number issued by the Division of Water Resources [redacted]
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-1819
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 8-29-02

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627