WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

P 3007

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 87686
Permit No.
Basin 137-B

NOTICE OF INTENT NO. 51085

1. OWNER Round Mountain Gold Corp.
MAILING ADDRESS P.O. Box 480
Round Mountain Nevada 89045

ADDRESS AT WELL LOCATION Round Mountain Gold Corporation Pit

2. LOCATION NW ¼ NW ¼ Sec. 15 T. 10 ☒S R. 44 E. Nye County

PERMIT NO. | Issued by Water Resources | Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☒ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Quartzite		0	260	260'
Phyllite		260'	605'	345'
Quartzite		605'	775'	170
Phyllite		775'	800	25'
Neat Cement		0	20'	20'
⅜ Hole Plug		20'	670'	650'
Sand Pack		670'	796'	126

Date started 8-21, 2002
Date completed 8-28, 2002

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
500	14		5 min.
600	16		5 min.
700	19		5 min.
800	50		5 min.

8. WELL CONSTRUCTION
Depth Drilled 800 Feet Depth Cased 796 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
12	Inches	0	Feet	20	Feet
6¼	Inches	20	Feet	240'	Feet
6⅛	Inches	240	Feet	720	Feet
6"		720		800	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8⅝		.188 wall	+1.6	20
2"		.188 wall	+1.4	796

Perforations:
Type perforation Vertical Slots
Size perforation .020 Slots
From 692 feet to 775 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 20'
Placement Method: ☐ Pumped ☒ Poured

Seal Type:
☒ Neat Cement
☐ Cement Grout
☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 670 feet to 796 feet

9. WATER LEVEL
Static water level 95 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality Clean

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Eklund Drilling Co. (Contractor)
Address P.O. Box 2748 (Contractor)
Elko Nevada 89803
Nevada contractor's license number issued by the State Contractor's Board 0030823
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1786
Signed Craig Dines (By driller performing actual drilling on site or contractor)
Date 8-28-02

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627