WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

**Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340**

OFFICE USE ONLY
Log No. 87729
Permit No.
Basin 212

NOTICE OF INTENT NO. 24302

1. OWNER WL HOMES LLC
MAILING ADDRESS 4435 S JONES #1
LAS VEGAS, NV 89103-3307

ADDRESS AT WELL LOCATION Desert Inn & Cabana
LAS VEGAS, NV

2. LOCATION SE ¼ SE ¼ Sec. 15 T. 21 N/S R. 62 E. CLARK County
PERMIT NO. DW1153 Issued by Water Resources
161-15-801-001,002 Parcel No. 161-15-701-001
JOHN LAING HOMES-DESERT INN Subdivision Name
PLANNED COMM.

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☒ Other Dewater

4. PROPOSED USE Dewater
☐ Domestic ☐ Irrigation ☐ Test
☒ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| 35-24" DEWATER WELLS | | | | |
| Silt | | 0' | 2' | 2' |
| Silt | xx | 2' | 26' | 24' |
| red clay | | 26' | 29' | 3' |
| white clay | | 29' | 30' | 1' |

RECEIVED
FEB 11 2003
LAS VEGAS OFFICE

Date started 1/6/03, 20
Date completed 1/28/03, 20

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| | | |

8. WELL CONSTRUCTION
Depth Drilled 30' Feet Depth Cased 30' Feet

HOLE DIAMETER (BIT SIZE)

| | From | To |
|---|---|---|
| 24" Inches | 0' Feet | 30' Feet |
| Inches | Feet | Feet |
| Inches | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| | | | | |
| | | | | |
| | | | | |

Perforations:
Type perforation MACHINE
Size perforation
From 20' feet to 30' feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☐ No
Depth of Seal
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☐ No
From 0' feet to 30' feet

9. WATER LEVEL
Static water level 2' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name ALLEN DRILLING INC. Contractor
Address 4015 WEST TOMPKINS
LAS VEGAS, NV 89103
Nevada contractor's license number issued by the State Contractor's Board 18917
Nevada driller's license number issued by the Division of Water Resources, the on-site driller ABDS2161
Signed By driller performing actual drilling on site or contractor
Date 2/4/03

(Rev. 12-01)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627