WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 817738
Permit No.
Basin 212

NOTICE OF INTENT NO. 24135

1. OWNER Charlotte L. Lee
MAILING ADDRESS
ADDRESS AT WELL LOCATION 5771 W. Rosada Wy. LV NEV. 89130

2. LOCATION NW ¼ SW ¼ Sec. 36 T. 19S N/S R. 60 E. Clark County
PERMIT NO. (Issued by Water Resources) Parcel No. 125-36-302-004 Subdivision Name

3. WORK PERFORMED
☐ New Well ☒ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Popcorn Caliche		0	10	
Hard Caliche		10	18	
Popcorn Caliche		18	40	
Hard Caliche		40	60	
Grey Clay		60	70	
Reddish Clay		70	80	
Popcorn Caliche		80	120	
Reddish Sandy Clay		120	125	
Caliche		125	175	
Caliche & Water	xxx	175	190	
Sandy Clay		190	310	
Caliche & Water	xxx	310		

Old well - Unscrewed drop pipe at Subsidence area (180) Ft. Perforate Pipe from 180 Ft. to 50 Ft. Cement brom bottom up, neat cement 02-17-03

RECEIVED
MAR 04 2003
LAS VEGAS OFFICE

Date started 2/14/03, 19
Date completed 2/17/03, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 605 375 Feet Depth Cased 605 375 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12 1/4	Inches	0 Feet	50 Feet
9 7/8	Inches	50 Feet	375 Feet
	Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8"	16.94	.188	+2	50
6 1/2	SRD PVC		+1	375

Perforations:
Type perforation Factory
Size perforation .032 Sieve Type
From 295 feet to 315 feet
From 335 feet to 355 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout
Gravel Packed: ☐ Yes ☒ No
From feet to feet

9. WATER LEVEL
Static water level 143 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cool °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Vernon H. Dimick (Contractor)
Address 5360 N. Bonita Vista St. (Contractor)
Las Vegas, Nev. 89149
Nevada contractor's license number issued by the State Contractor's Board 10062
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 552
Signed V H Dimick (By driller performing actual drilling on site or contractor)
Date 02-24-03

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627