

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 27746
 Permit No. _____
 Basin 212

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in
 accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 23370

1. OWNER Langan Engineering ADDRESS AT WELL LOCATION Furnberry Towers
 MAILING ADDRESS 2777 Paradise Road Paradise Road
Las Vegas NV 89109 Las Vegas NV
 2. LOCATION NE 1/4 NW 1/4 Sec 10 T 21 SR 61 E County Clark
 PERMIT NO _____ Issued by Water Resources Parcel No. 162-09-602-006 Subdivision Name _____

3. WORK PERFORMED New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Brown silty sand, some fine gravel		0'	3.0'	3.0'
White gray fine gravelly sand, silt and clay		3.0'	16.0'	13.0'
Brown sand and fine gravel, some silt and clay		16.0'	19.0'	3.0'
Light brown silty clay		19.0'	21.0'	2.0'
Light brown fine sand and clay		21.0'	22.5'	1.5'
Light brown fine sandy clay		22.5'	25.0'	2.5'
Brown clay with fine sand and silt		25.0'	26.5'	1.5'

8. WELL CONSTRUCTION
 Depth Drilled 26.5 Feet Depth Cased 26.5 Feet
 HOLE DIAMETER (BIT SIZE)
 From 6 Inches To 0 Feet
0 Inches 26.5 Feet
_____ Inches _____ Feet
_____ Inches _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2.375		0.308	0	22

Perforations:
 Type perforation Factory slot PVC
 Size perforation 0.020"
 From 2 feet to 22 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 1.5 ft. Neat Cement
 Placement Method Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 1.5 feet to 22 feet

9. WATER LEVEL
 Static water level 17 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATE
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Converse Consultants Contractor
 Address 731 Pilot Road, Ste. H, Las Vegas NV 89119 Contractor

Date started October 12, 2002
 Date completed October 12, 2002

7. WELL TEST DATA

TEST METHOD	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pumped <input type="checkbox"/> Air Lift			

Nevada contractor's license number
 Issued by the State Contractor's Board 48947
 Nevada driller's license number issued by the
 Division of Water Resources, the on-site driller M 1589
 Signed Ronald T. Pyles
 By driller performing actual drilling on-site or contractor
 Date 2/12/03

RECEIVED
 FEB 13 2003
 LAS VEGAS OFFICE