WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 87748
Permit No. 64425
Basin 162

NOTICE OF INTENT NO. 23309

OWNER Delbert Schmidt
MAILING ADDRESS 3451 E. Tillman
Pahrump, NV 89060

ADDRESS AT WELL LOCATION 3451 E. Tillman

2. LOCATION SE 1/4 SW 1/4 Sec. 31 T 21S N/S R 54E E Nye County
PERMIT NO. 64425 (Issued by Water Resources) | 45-441-13 (Parcel No.) | Cal-Vista (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[ ] Domestic [X] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
brown loam and gravel		0	65	65
brown loam	x	65	205	140

Desi: Please add Permit No. 64425 to Bobby D.

RECEIVED
FEB 10 2003
LAS VEGAS OFFICE

Date started 11/4/02, 19__
Date completed 11/4/02, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 205 Feet Depth Cased 205+1 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
11	Inches	0	Feet	205	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	3.7	.280	0	205

Perforations:
Type perforation sawcut
Size perforation .188
From 170 feet to 205 feet
From ___ feet to ___ feet
From ___ feet to ___ feet
From ___ feet to ___ feet
From ___ feet to ___ feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 205 feet

9. WATER LEVEL
Static water level 122 feet below land surface
Artesian flow ___ G.P.M. ___ P.S.I.
Water temperature cool °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Strickland Construction Co., Inc. (Contractor)
Address 5801 S. Homestead (Contractor)
Pahrump, NV 89048
Nevada contractor's license number issued by the State Contractor's Board 40277
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2086
Signed Larry Strickland (By driller performing actual drilling on-site or contractor)
Date 12-1-02