WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 87778
Permit No. 44473
Basin 220

NOTICE OF INTENT NO. 22558

1. OWNER Moapa Valley Dairy Farms
MAILING ADDRESS Box 488
Overton, NV. 89040
ADDRESS AT WELL LOCATION Overton

2. LOCATION NE ¼ NE ¼ Sec. 13 T. 16S N/S R. 67 E. Clark County
PERMIT NO. 44473 (Issued by Water Resources) Parcel No. N/A Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☒ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Attemped to remove				
casing-would not pull.				
Perforated 0 to 140 ft.				
4 Rows, 12" centers.				
Set 2" tremie pipe				
at 140 ft. Pumped				
10 yards of neat				
cement to fill well.				

RECEIVED
FEB 27 2003
LAS VEGAS OFFICE

Date started February 24, 2003 XX
Date completed February 25, 2003 XX

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled ____ Feet Depth Cased ____ Feet

HOLE DIAMETER (BIT SIZE)

Inches	From Feet	To Feet
12	-0-	140

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)

Perforations:
Type perforation Mills Knife
Size perforation 1/4 x 2
From -0- feet to 140 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 140
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☐ Yes ☐ No
From ____ feet to ____ feet

9. WATER LEVEL
Static water level ____ feet below land surface
Artesian flow ____ G.P.M. ____ P.S.I.
Water temperature ____ °F Quality ____

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Thompson Drilling Co., Inc. (Contractor)
Address 7227 Hauck St. (Contractor)
Las Vegas, NV. 89118
Nevada contractor's license number issued by the State Contractor's Board 0004286A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 290
Signed Richard K. Thompson (By driller performing actual drilling on site or contractor)
Date February 26, 2003

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627