

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**



OFFICE USE ONLY

Log No. 87792  
 Permit No. \_\_\_\_\_  
 Basin 101

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. **50594**

1. OWNER **Hammond Homes & Construction** ADDRESS AT WELL LOCATION **4300 Santa Fe Road,**  
 MAILING ADDRESS **1780 Lattin Road** **Fallon, NV 89406**  
 2. LOCATION SE 1/4 SE 1/4 Sec. 28 T 19N N/S R 28E E Churchill County  
 PERMIT NO. \_\_\_\_\_ Parcel No. **008-401-69** Subdivision Name \_\_\_\_\_  
 Issued by Water Resources \_\_\_\_\_

3. WORK PERFORMED  New Well  Replace  Recondition  Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  Domestic  Municipal/Industrial  Irrigation  Monitor  Test  Stock  Cable  Rotary  RVC  Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Brown sand		0	40	40
Gray Clay		40	49	9
Gray Sand		49	65	16
Gray Clay		65	67	2
Gray Sand		67	71	4
Gray Clay		71	73	2
Brown sand		73	82	9
Gray Clay		82	86	4
Gray Sand		86	90	4
Brown CLay		90	93	3
Green Clay		93	98	5
Gray Clay		98	110	12
Gray Sand		110	113	3
Gray Clay		113	121	8
Gray Sand		121	125	4
Gray Clay		125	127	2
Brownish Sand		127	145	18
Brown Sand	XX	145	152	7
Brown Sand		152	162	10
Brown Clay		162	180	18
Green Clay		180	195	15
Brown Sand	XX	195	207	12

8. WELL CONSTRUCTION  
 Depth Drilled 207 Feet Depth Cased 207 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 10 Inches To 207 Feet  
 \_\_\_\_\_ Inches Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	1	10
6 PVC	3.92	.258	10	207

Perforations:  
 Type perforation **Saw Cut**  
 Size perforation 1/8  
 From 203 feet to 207 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type: \_\_\_\_\_  
 Depth of Seal 160  Neat Cement  
 Placement Method:  Pumped  Poured  Cement Grout  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 160 feet to 207 feet

9. WATER LEVEL  
 Static water level 23 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature cool °F Quality unknown

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name **Parsons Drilling, Inc.** Contractor  
 Address **P.O. Box 1265** Contractor  
**Fallon Nv. 89407-1265**  
 Nevada contractor's license number issued by the State Contractor's Board **29064**  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller **2212**  
 Signed [Signature]  
 By driller performing actual drilling on-site or contractor  
 Date **07/10/2002**

Date started **07/09/2002**, 19  
 Date completed **07/09/2002**, 19

7. WELL TEST DATA

TEST METHOD:	TEST METHOD:		Time (Hours)
	G.P.M.	Draw Down (Feet Below Static)	
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>20</u>	<u>1hr</u>	