

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 21909

1. OWNER Richard Veal ADDRESS AT WELL LOCATION side Burro Ln. Dyer, Nevada 89010
 MAILING ADDRESS P.O. Box 249 Dyer, Nevada 89010-0249
 2. LOCATION N.E. 1/4 S.W. 1/4 Sec. 6 T. 4 N. R. 36 E. E. Esmeralda County
 PERMIT NO. 7-681-13- lot 15 Fish Lake Valley Ranches
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
brown silty clay		0	30	30
sandy gravel		30	40	10
sandy clay		40	100	60
course sand	✓	100	125	25
sand & clay		125	220	95
course sand	✓	220	228	8
sandy clay		228	260	32
sand	✓	260	286	26
sticky clay		286	288	2
loose sand	✓	288	315	27

8. WELL CONSTRUCTION
 Depth Drilled 315 Feet Depth Cased 305 Feet
 HOLE DIAMETER (BIT SIZE)
 From 0 To 315
10 Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	71	6
6 5/8	PVC	SDR21, 200 PSI	6	305

Perforations: saw cut horizontal 2 rows
 Type perforation _____
 Size perforation 3/32"
 From 145 feet to 305 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 305 feet

9. WATER LEVEL
 Static water level 98 feet below land surface
 Artesian flow _____ G.P.M. 125 P.S.I.
 Water temperature _____ °F Quality good

Date started 3-27 2002
 Date completed 4-15 2002

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift			
	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
	175	60	1hr
	250	110	1hr.
	30	125	2hr.

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name MARANATHA DRILLING & PUMP SERVICE Contractor
 Address 22393 Hwy 6 Benton, CA. 93512 Contractor
 Nevada contractor's license number 039576 issued by the State Contractor's Board
 Nevada driller's license number issued by the 1238 Division of Water Resources, the on-site driller
 Signed Russell Hill
 By driller performing actual drilling on site or contractor
 Date August 27 - 2002

RECEIVED
 02 SEP - 3 PM 1:33
 CIVIL ENGINEERS OFFICE

RECEIVED
 MAR 05 2003

LAS VEGAS OFFICE

