

202

WHITE-DIVISION OF WATER RESOURCES  
CANARY-CLIENT'S COPY  
PINK-WELL DRILLER'S COPY

STATE OF NEVADA  
DIVISION OF WATER RESOURCES

OFFICE USE ONLY  
Log No. 877099  
Permit No. \_\_\_\_\_  
Basin 212

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT  
Please complete this form in its entirety in  
accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 48456

1. OWNER Hanson Aggregate ADDRESS AT WELL LOCATION 1301 American Pacific  
MAILING ADDRESS 1764 Clearwater Canyon Henderson, NV 89012  
2. LOCATION SW 1/4 SE 1/4 Sec. 09 T. 22 N10R 62 E Clark County  
PERMIT NO. No tag Issued by Water Resources | 178-09-80004 Parcel No. | \_\_\_\_\_ Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
4. PROPOSED USE (Unknown)  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG				
Material	Water Strata	From	To	Thick-ness
perforate well from bottom 200 to 50' static water level 200		200	50	
pumped neat cement 8 yds from bottom to top		200	surface	
RECEIVED				
MAR 03 2003				
LAS VEGAS OFFICE				

8. WELL CONSTRUCTION  
Depth Drilled 200 Feet Depth Cased 200 Feet  
HOLE DIAMETER (BIT SIZE)  
From \_\_\_\_\_ To \_\_\_\_\_  
12 Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
\_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
\_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE				
Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>12</u>				

Perforations:  
Type perforation \_\_\_\_\_  
Size perforation \_\_\_\_\_  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  Neat Cement  
Depth of Seal \_\_\_\_\_  Cement Grout  
Placement Method:  Pumped  Concrete Grout  
 Poured  
Gravel Packed:  Yes  No  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet

9. WATER LEVEL  
Static water level 20 feet below land surface  
Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ B.S.I.  
Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

Date started February 25, 2003  
Date completed March 5, 2003

7. WELL TEST DATA			
TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name Testing Engineers of Nevada Contractor  
Address 6280 S. Valley View Las Vegas, NV 89118 Contractor  
Nevada contractor's license number #0054243 issued by the State Contractor's Board  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2229  
Signed [Signature]  
By driller performing actual drilling on site or contractor  
Date 3-5-03