

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER ACH PMLINARIC ADDRESS AT WELL LOCATION DIAMOND AV. & WINNEBAGO ST. SANDY VALLEY NV. CLARK  
 MAILING ADDRESS \_\_\_\_\_  
 2. LOCATION NE 1/4 NE 1/4 Sec. 21 T. 24 N/S R. 56 E County CLARK  
 PERMIT NO. 200-21-000-002 Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SANDY LOAM		0	6	6
CLAY & GRAVEL		6	34	28
CLAY		34	46	12
CALICHE		46	51	5
CLAY & GRAVEL		51	110	59
CALICHE	W.B	110	122	12
CLAY		122	136	14
CALICHE	W.B	136	141	5
CLAY		141	215	74
CALICHE	W.B	215	222	7
CLAY		222	290	68
CALICHE	W.B	290	300	10
CLAY		300	318	18
CALICHE	W.B	318	326	8
CLAY		326	336	10
CALICHE	W.B	336	342	6
CLAY		342	350	8

RECEIVED  
 MAR 07 2003  
 LAS VEGAS OFFICE

8. WELL CONSTRUCTION  
 Depth Drilled 350 Feet Depth Cased 350 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From To  
10 5/8 Inches 0 Feet 110 Feet  
9 7/8 Inches 110 Feet 350 Feet  
 Casing Schedule  

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>4.33</u>	<u>3/16</u>	<u>0</u>	<u>350</u>

 Perforations:  
 Type perforation SAW CUT  
 Size perforation 8 INCH BY 6 INCH  
 From 340 feet to 280 feet  
 From 220 feet to 200 feet  
 From 180 feet to 160 feet  
 From 140 feet to 120 feet  
 Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 350 feet to 50 feet

Date started 1-16 2003  
 Date completed 1-22 2003

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

9. WATER LEVEL  
 Static water level 107 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature COOL °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name BUDGET DRILLING CO Contractor  
 Address P.O. Box 3505 Primm NV. 89041 Contractor  
 Nevada contractor's license number issued by the State Contractor's Board 40020  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1573  
 Signed Arnie Brown  
 By driller performing actual drilling on site or contractor  
 Date 2-3-2003