COPIES TO
- DIVISION OF WATER RESOURCES
- CLIENT'S COPY
- WELL DRILLER'S COPY

PRINT OR TYPE ONLY

STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 87814
Permit No.
Basin 105
NOTICE OF INTENT NO. 42046

1. OWNER KIM POSNIEN CONSTRUCTION
MAILING ADDRESS 440 FOOTHILLS RD
GARDNERVILLE , NV 89410

ADDRESS AT WELL LOCATION ~~1484 TOLLER RD~~
GARDNERVILLE , NV 89410 1420 Stonegate Ct.

2. LOCATION ~~SW~~ SE ¼ ~~NW~~ SW ¼ Sec 34 T 13 N R 20 E DOUGLAS County
PERMIT NO. Issued by Water Resources
1320-34-02-~~003~~ 013 Parcel No.
Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
HARDPAN CLAY		0	3	3
BROW CLAY		3	36	33
LARGE GRAVELS		36	78	52
BROWN CLAY ZONE		78	183	105
SILTY SANDS				
FRACTURED GRAVELS	XXX	183	220	37
COURSE SANDS				

RECEIVED 02 MAY 31 AM 8:26 STATE ENGINEER'S OFFICE

Date started 5/18 , 20 02
Date completed 5/21 , 20 02

7. WELL TEST DATE

TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
35+	35	3 HRS

8. WELL CONSTRUCTION
Depth Drilled 220 Feet Depth Cased 220 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 3/4 Inches	0 Feet	220 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	.188	0	220

Perforations:
Type perforation FACTORY MILL SLOT
Size perforation 3 X 3/32
From 200 feet to 220 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 100
Placement Method: ☒ Pumped ☐ Poured
Gravel Packed: ☒ Yes ☐ No
From 100 feet to 220 feet

Seal Type:
☒ Neat Cement
☐ Cement Grout
☐ Concrete Grout

9. WATER LEVEL
Static water level 25 feet below land surface
Artesian flow G.P.M ~~35+~~ P.S.I
Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name CAPITAL CITY WELL DRILLING (CONTRACTOR)
Address 20 KIT KAT DRIVE (CONTRACTOR)
CARSON CITY , NV 89706
Nevada contractor's license number issued by the State Contractor's Board 41775
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2157
Signed Michael D. Hack
By driller performing actual drilling on site or contractor
Date 5/20/02

(Rev 3-91) USE ADDITIONAL SHEETS IF NECESSARY

Forms Provided by Forms-On-A-Disk, Inc. - Dallas, Texas - (214) 340-9429