COPIES TO
- DIVISION OF WATER RESOURCES
- CLIENT'S COPY
- WELL DRILLER'S COPY

PRINT OR TYPE ONLY

STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 87821
Permit No.
Basin 105

NOTICE OF INTENT NO. 46414

1. OWNER MIKE SWIFT CONSTRUCTION
MAILING ADDRESS 971 MARRIANNE
GARDNERVILLE, NV 89410

ADDRESS AT WELL LOCATION 660 FRONTAGE RD
GARDNERVILLE, NV 89410

2. LOCATION SW ¼ SW ¼ Sec 24 T 12 N R 20 E DOUGLAS County

PERMIT NO. (Issued by Water Resources) | 1220-24-410-002 (Parcel No.) | RUHENSTROTH (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
LARGE BOULDER		0	4	4
LARGE BOULDERS AND LARGE COBBLES		4	30	26
COBBLES AND OBSIDIAN BOULDERS		30	85	55
OBSIDIAN GRAVELS		85	130	45
CLAY SEAMS FRACTURED GRAVELS SMALL BOULDERS	X	130	140	10
CLAY SEAM		140	145	5
VERY FRACTURED OBSIDIAN GRAVELS	XXX	145	180	35

RECEIVED 02 AUG 26 AM 9:36 STATE ENGINEER'S OFFICE

Date started 8/9, 20 02
Date completed 8/11, 20 02

7. WELL TEST DATE

TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
25+	30	3 HRS

8. WELL CONSTRUCTION

Depth Drilled 180' Feet Depth Cased 180' Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 3/4 Inches	0 Feet	180 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	.188	0	180

Perforations:
Type perforation FACTORY MILL SLOT
Size perforation 3 X 3/32
From 160 feet to 180 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No Seal Type:
Depth of Seal 100 ☒ Neat Cement
Placement Method: ☒ Pumped ☐ Cement Grout
☐ Poured ☐ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 100 feet to 180 feet

9. WATER LEVEL
Static water level 65 feet below land surface
Artesian flow G.P.M 25+ P.S.I
Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name CAPITAL CITY WELL DRILLING (CONTRACTOR)
Address 20 KIT KAT DRIVE (CONTRACTOR)
CARSON CITY, NV 89706
Nevada contractor's license number issued by the State Contractor's Board 41775
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2157
Signed Rick Crane
By driller performing actual drilling on site or contractor
Date 8/11/02

(Rev.3-91) USE ADDITIONAL SHEETS IF NECESSARY

Forms Provided by Forms-On-A-Disk, Inc. · Dallas, Texas · (214) 340-9429