WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 87841
Permit No.
Basin 061

NOTICE OF INTENT NO. 50858

1. OWNER Barrick Goldstrike Mines NA-17
MAILING ADDRESS P.O. Box 29
Elko, NV 89803

ADDRESS AT WELL LOCATION Barrick Goldstrike minesite, north of Carlin, NV.

2. LOCATION SE 1/4 NW 1/4 Sec. 35 T 36N N/S R 49E E Eureka County
PERMIT NO. M/O-256 (Issued by Water Resources) | N/A (Parcel No.) | N/A (Subdivision Name)

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Note: Original construction had hole plug from 50 to 513'.				
Abandoned by pumping abantonite from T.D. to static water level, then poured hole plug, and capped with neat cement.				
Quantities Used:				
Cement: 7.1 cu.ft.		0	81	81
Hole plug: 18 cu.ft.		81	287	206
Abantonite: 143 cu.ft.		287	648	361

Date started 5/24/2002, 19__
Date completed 5/24/2002, 19__

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 648 Feet Depth Cased 648 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
14	Inches	0	Feet	20	Feet
10	Inches	20	Feet	648	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
10	28.04	0.250	+2	20
4.5	2.41	Sch. 40	+1	648

Perforations:
Type perforation Slot
Size perforation 0.020"
From 548 feet to 648 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50'
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 513 feet to 640 feet

9. WATER LEVEL
Static water level 498 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Lang Exploratory Drilling (Contractor)
Address P.O. Box 5279 (Contractor)
Elko, NV 89802-5279
Nevada contractor's license number issued by the State Contractor's Board 0021976
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1995
Signed Guadalupe Jacobo (By driller performing actual drilling on-site or contractor)
Date 5/29/02

USE ADDITIONAL SHEETS IF NECESSARY

B.ST-L