

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 87846
 Permit No. 55150
 Basin 061

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 50810-

1. OWNER Barrick Goldstrike Mines VD98-6 ADDRESS AT WELL LOCATION Barrick Goldstrike minesite, north of Carlin, NV.
 MAILING ADDRESS P.O. Box 29
Elko, NV 89803

2. LOCATION SW 1/4 NE 1/4 Sec. 30 T 36N N/S R 50E E Eureka County
 PERMIT NO. 55150 Issued by Water Resources Parcel No. N/A Subdivision Name N/A

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Original construction had hole plug from 101' to 208'.				
Abandoned by pumping abantonite via tremie from 900' to 642', poured hole plug plus abantonite to 50', placed a 10' cement plug, poured hole plug to 20', capped with neat cement. Pumped 2" sounder full of ment.				
Quantities Used:				
Cement: 4 cu.ft.		0	20	20
Hole plug: 4 cu.ft.		20	40	20
Cement: 3 cu.ft.		40	50	10
Hole plug: 134 cu.ft.		50	642	592
Abantonite: 164 cu.ft.		642	900	258
Sounder took 22 cu.ft. of cement.				

8. WELL CONSTRUCTION

Depth Drilled 910 Feet Depth Cased 900 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
20.5 Inches	0	30
12.75 Inches	30	390
12.25 Inches	390	910

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
14	45.61	0.3125	0	30
6.625	17.02	0.250	+2	900
2.375	3.65	0.154	+2	880

Perforations:
 Type perforation 6": Louver 2": Slot
 Size perforation 0.125"
 From 6": 217.9 feet to 900 feet
 From 2": 860 feet to 880 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 101' Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 208 feet to 910 feet

9. WATER LEVEL
 Static water level 642 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Lang Exploratory Drilling Contractor
 Address P.O. Box 5279 Contractor
Elko, NV 89802-5279
 Nevada contractor's license number issued by the State Contractor's Board 0021976
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1995
 Signed Quadalupa Jacobs
 By driller performing actual drilling on-site or contractor
 Date 8/2/02

Date started 7/27/2002, 19
 Date completed 7/27/2002, 19

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

B.S.T.L