

STATE OF NEVADA
 DIVISION OF WATER RESOURCES

OFFICE USE ONLY
 Log No. 87850
 Permit No. 58355
 Basin 061

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 50808

1. OWNER Barrick Goldstrike Mines VD98-1
 MAILING ADDRESS P.O. Box 29
Elko, NV 89803
 ADDRESS AT WELL LOCATION Barrick Goldstrike
minesite, north of Carlin, NV.

2. LOCATION NE 1/4 NE 1/4 Sec. 30 T 36N N/S R 50E E Eureka County
 PERMIT NO. 58355 Issued by Water Resources Parcel No. N/A Subdivision Name N/A

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Abandoned by pumping cement via tremie from 660' to 455', poured hole plug and abantonite to 119', placed a 10' cement plug, poured clean fill to 20', and capped with neat cement.</u>				
<u>Quantities Used:</u>				
<u>Cement: 4 cu.ft.</u>		<u>0</u>	<u>20</u>	<u>20</u>
<u>Fill: 17.5 cu.ft.</u>		<u>20</u>	<u>109</u>	<u>89</u>
<u>Cement: 2 cu.ft.</u>		<u>109</u>	<u>119</u>	<u>10</u>
<u>Hole plug: 69 cu.ft.</u>		<u>119</u>		
<u>Abantonite: 55 cu.ft.</u>			<u>455</u>	
<u>Cement: 46 cu.ft.</u>		<u>455</u>	<u>660</u>	<u>205</u>

8. WELL CONSTRUCTION
 Depth Drilled 670 Feet Depth Cased 660 Feet
 HOLE DIAMETER (BIT SIZE)
 From 17.5 Inches 0 Feet 40 Feet
9.875 Inches 40 Feet 670 Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>12.75</u>	<u>49.56</u>	<u>0.375</u>	<u>0</u>	<u>40</u>
<u>6.625</u>	<u>17.02</u>	<u>0.250</u>	<u>+1</u>	<u>660</u>

Perforations:
 Type perforation Louwer
 Size perforation 0.125"
 From 120 feet to 660 feet
 From _____ feet to _____ feet

Surface Seal: Yes No
 Depth of Seal 100'
 Placement Method: Pumped Poured
 Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Gravel Packed: Yes No
 From 100 feet to 670 feet

9. WATER LEVEL
 Static water level 480 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Lang Exploratory Drilling Contractor
 Address P.O. Box 5279 Contractor
Elko, NV 89802-5279
 Nevada contractor's license number issued by the State Contractor's Board 0021976
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1995
 Signed Guadalupe Jacobo
 By driller performing actual drilling or site or contractor
 Date 8/6/02

Date started 8/1/2002, 19
 Date completed 8/2/2002, 19

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

B.S.T.L