

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 87851
 Permit No. 58355
 Basin 061

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 50808

1. OWNER Barrick Goldstrike Mines EW-11
 MAILING ADDRESS P.O. Box 29
Elko, NV 89803

ADDRESS AT WELL LOCATION Barrick Goldstrike
minesite, north of Carlin, NV.

2. LOCATION NE 1/4 NE 1/4 Sec. 30 T 36N N/S R 50E E Eureka County

PERMIT NO. 58355 Issued by Water Resources Parcel No. N/A Subdivision Name N/A

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Abandoned by pumping neat cement via tremie from 480' to 371', (got a good tag at 371'), pumped abantonite and poured hole plug to 150', placed a 10' cement plug, poured clean fill to 20', capped with neat cement.				
Quantities Used:				
Cement: 16 cu.ft.		0	20	20
Fill: 94 cu.ft.		20	140	120
Cement: 8 cu.ft.		140	150	10
Hole plug: 69 cu.ft.		150		
Abantonite: 164 cu.ft.			371	
Cement: 105 cu.ft.		371	480	109

8. WELL CONSTRUCTION
 Depth Drilled 500 Feet Depth Cased 480 Feet

HOLE DIAMETER (BIT SIZE)

From		To	
<u>31</u> Inches	<u>0</u> Feet	<u>40</u> Feet	<u>500</u> Feet
<u>19</u> Inches	<u>40</u> Feet		

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>24</u>	<u>63</u>	<u>0.250</u>	<u>0</u>	<u>40</u>
<u>12.75</u>	<u>50</u>	<u>0.375</u>	<u>0</u>	<u>480</u>

Perforations:
 Type perforation Slot
 Size perforation 0.125"

From	To	From	To
<u>160</u> feet	<u>200</u> feet	<u>280</u> feet	<u>320</u> feet
<u>400</u> feet	<u>480</u> feet		

Surface Seal: Yes No
 Depth of Seal 100'
 Placement Method: Pumped Poured
 Seal Type: Neat Cement Cement Grout Concrete Grout
 Gravel Packed: Yes No
 From 100 feet to 500 feet

9. WATER LEVEL
 Static water level 231 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

Date started 8/1/2002, 19
 Date completed 8/1/2002, 19

7. WELL TEST DATA

TEST METHOD:	Bailer		Pump		Air Lift	
	G.P.M.	Draw Down (Feet Below Static)	G.P.M.	Draw Down (Feet Below Static)	G.P.M.	Time (Hours)

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Lang Exploratory Drilling Contractor
 Address P.O. Box 5279 Contractor
Elko, NV 89802-5279
 Nevada contractor's license number issued by the State Contractor's Board 0021976
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1995
 Signed Guadalupe Jacoto
 By driller performing actual drilling on-site or contractor
 Date 8/2/02

B.S.T.L.