

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 87836
 Permit No. 61407
 Basin 061

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 50805

1. OWNER Barrick Goldstrike Mines Amend. VD97-26
 MAILING ADDRESS P. O. Box 29
Elko, NV 89803

ADDRESS AT WELL LOCATION Barrick Goldstrike minesite, north of Carlin, NV.

2. LOCATION SE 1/4 NE 1/4 Sec. 30 T 36N N/S R 50E E Eureka County
 PERMIT NO. 61407 Issued by Water Resources Parcel No. N/A Subdivision Name N/A

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
This well had been buried. After uncovering, found that the casing was bridged at 292'. Drilled the fill out using a 5.25" bit, at 300' the bit acted like it was on steel, and some steel was in the returns. As hole was advanced, it seemed to be in native material. By 420' it was apparent that the bit was no longer inside the casing. Abandoned by pumping abantonite from 420' to 150', poured hole plug to 20', and capped with neat cement.				
Quantities Used:				
Cement: 2.4 cu.ft.				
Hole plug: 34.5 cu.ft.				
Abantonite: 82 cu.ft.				

8. WELL CONSTRUCTION

Depth Drilled 860 Feet Depth Cased 857 Feet

HOLE DIAMETER (BIT SIZE)

From		To	
<u>17</u> Inches	<u>0</u> Feet	<u>40</u> Feet	
<u>9.875</u> Inches	<u>40</u> Feet	<u>860</u> Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>12.75</u>	<u>33.38</u>	<u>0.250</u>	<u>0</u>	<u>40</u>
<u>6.625</u>	<u>17.02</u>	<u>0.250</u>	<u>+2</u>	<u>857</u>

Perforations:
 Type perforation Louver
 Size perforation 0.125"

From	To
<u>116.5</u> feet	<u>857</u> feet

Surface Seal: Yes No
 Depth of Seal 102.8' Seal Type: Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 102.8 feet to 860 feet

9. WATER LEVEL
 Static water level No Reading feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Lang Exploratory Drilling Contractor
 Address P.O. Box 5279 Contractor
Elko, NV 89802-5279
 Nevada contractor's license number issued by the State Contractor's Board 0021976
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1995
 Signed Guadalupe Jacabo
 By driller performing actual drilling on-site or contractor
 Date 8/5/02

Date started 8/3/2002, 19
 Date completed 8/4/2002, 19

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

BST.L