

OFFICE USE ONLY
 Log No. 37891
 Permit No. 25971
 Basin. 092-B

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 50400

1. OWNER RENO "307"
 MAILING ADDRESS 1975 Hamilton Avenue #32
 San Jose, California 95125
 ADDRESS AT WELL LOCATION 7900 North Virginia Street
 Reno, Nevada 89506
 2. LOCATION NW 1/4 NW 1/4 Sec. 15 T. 20N N/S R. 19 E. Washoe County
 PERMIT NO. 25971 082-180-31 Between Golden Valley & Raleigh Heights
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Well abandonment (N well in building) (WCo "B")				
8 5/8" dia well - 227 feet deep				
4-11-02				
Measure static water level @102 feet				
Measure total depth @211 feet				
Bail from 211 to 239 feet. Well was bailed 12 feet below bottom of casing. Bailer was stuck in bottom. Called Tim Hunt NDWR to OK suspend bailing. OK.				
4-12-02				
Run Mills Knife Perforator to 58 feet, perforate 4 holes around on 6" intervals back to 50 feet. 5/16x3" slots.				
Mix & pump & tremie 50 sacks cement.				
4-15-02				
Measure static water level @101 feet				
Measure cement level @119 feet				
Mix, pump & tremie 40 sacks cement to fill casing to surface.				
Concrete top to match concrete floor.				
Materials:				
90 sacks Portland Cement Type II				
1 sack concrete mix				
Equipment:				
Mills Knife Perforator				
Grout pump & mixer				
Tremie pipe				
5T Smeal pump setter (continued below)				
Date started April 11, 2002, 19.....				
Date completed April 15, 2002, 19.....				

8. WELL CONSTRUCTION
 Depth Drilled..... Feet Depth Cased..... Feet
 HOLE DIAMETER (BIT SIZE)
 From To
 Inches Feet Feet
 Inches Feet Feet
 Inches Feet Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)

 Perforations:
 Type perforation.....
 Size perforation.....
 From..... feet to..... feet
 Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal.....
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From..... feet to..... feet

7. WELL TEST DATA
 TEST METHOD: Bailer Pump Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Continued:			
Location:			
63 feet S of N boundry			
Referred to as the N well in building			

9. WATER LEVEL
 Static water level..... feet below land surface
 Artesian flow..... G.P.M. P.S.I.
 Water temperature..... °F Quality.....
 10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name WAYNE DRILLING, INC.
 Contractor
 Address P.O. BOX 12370
 Contractor
 RENO, NEVADA 89510
 Nevada contractor's license number issued by the State Contractor's Board..... 0022549
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller..... 908/923
 Signed *Wayne Drilling, Inc.*
 By driller performing actual drilling on site or contractor
 Date May 2, 2002