

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 50406

1. OWNER NANCY HORVATH ADDRESS AT WELL LOCATION 8840 Spearhead Way  
 MAILING ADDRESS 8840 Spearhead Way Reno, Nevada 89506  
 2. LOCATION NW 1/4 NE 1/4 Sec. 14 T. 20N N/S R. 19 E. Washoe County Golden Valley  
 PERMIT NO. 082-512-11 Issued by Water Resources Parcel No.                      Subdivision Name                     

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other                       
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other                     

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
WELL DEEPENING				
Fill, rusty granite sands		87	88	1
Open hole, dumping gravel		88	105	17
Granite		105	135	30
Fracture (app 3 GPM)	X	135	137	2
Granite		137	144	7
Fracture (app 2 GPM)	X	144	146	2
Granite		146	190	44
Fracture (app 10 GPM)	X	190	191	1
Gray hard granite		191	210	19
Rusty weathered granite (NO WATER)		210	216	6
Gray hard granite		216	230	14
Fracture granite with clay streaks	X	230	246	16
Gray granite		246	248	2

8. WELL CONSTRUCTION  
 Depth Drilled 248 Feet Depth Cased 248 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 6 1/8 Inches To 88 Feet 248 Feet  
 Inches Feet Feet  
 Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
5"OD		.188	0	248

Perforations:  
 Type perforation factory sawed slot  
 Size perforation 3/32 x 3 x 5 around  
 From 140 feet to 160 feet  
 From 180 feet to 200 feet  
 From 220 feet to 240 feet  
 From                      feet to                      feet  
 From                      feet to                      feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout  
 Depth of Seal deepening  
 Placement Method:  Pumped  Poured  
 Gravel Packed:  Yes  No  
 From 88 feet to 248 feet

9. WATER LEVEL  
 Static water level 94 feet below land surface  
 Artesian flow                      G.P.M. 30+ P.S.I.  
 Water temperature cold °F Quality clear

Date started May 9, 2002, 19.....  
 Date completed May 10, 2002, 19.....

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>30+</u>		

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name WAYNE DRILLING, INC. Contractor  
 Address P.O. BOX 12370 Contractor  
RENO, NEVADA 89510  
 Nevada contractor's license number 0022549 issued by the State Contractor's Board.  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923  
 Signed Wayne Drilling, Inc. By driller performing actual drilling on site or contractor  
 Date May 20, 2002