WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 87903
Permit No.
Basin Ø44

NOTICE OF INTENT NO. 40235

1. OWNER Anglo Gold
MAILING ADDRESS HC-31 Box 78 ELKO, NV. 89801
ADDRESS AT WELL LOCATION Anglo Gold HC-31 Box 78 ELKO, NV. 89801

2. LOCATION NE ¼ NW ¼ Sec. 17 T. 40 ⊗S R. 54 ⊗ ELKO County
PERMIT NO. UNEV 93214 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE Injection
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☒ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Snow canyon formation soft		0'	250'	250'
Roberts mtn. formation mod soft		250'	780'	530'
1 Hansen Creek formation Hard		780'	790'	10'
3 Hansen Creek formation Hard		790'	840'	50'
4 Hansen Creek formation Hard		840'	900'	60'
Flush Joint Steel casing				

Date started 6-28-02
Date completed 7-2-02

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
	60 GPM	

8. WELL CONSTRUCTION
Depth Drilled ____ Feet Depth Cased ____ Feet

HOLE DIAMETER (BIT SIZE)

	From	To
12" Inches	0' Feet	20' Feet
8½" Inches	20' Feet	900' Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4.5	11.35	.250	0'	

Perforations:
Type perforation Vert. Slot
Size perforation ⅛ by 2
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50'
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☒ No
From ____ feet to ____ feet

9. WATER LEVEL
Static water level 450' feet below land surface
Artesian flow -NO 60 G.P.M. 300 P.S.I.
Water temperature 54° °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Ward Weaver (Contractor)
Address 2305 Last Chance Rd. ELKO, NV. 89801 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 0030630
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1676
Signed Ward Weaver (By driller performing actual drilling on site or contractor)
Date

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627