WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 87908
Permit No.
Basin 052

NOTICE OF INTENT NO. 50815

1. OWNER Pilot Corporation MW-1
MAILING ADDRESS P.O. Box 10146
Knoxville, TN 37939

ADDRESS AT WELL LOCATION 791 10th Street, Carlin, NV.

2. LOCATION SE 1/4 NE 1/4 Sec. 27 T 33N N/S R 52E E Elko County
PERMIT NO. NDEP 99-211 (Issued by Water Resources) | 002-030-028 (Parcel No.) | N/A (Subdivision Name)

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other HSA

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Cut surface vault and casing off 3" below asphalt pavement. Abandoned by pumping neat cement via tremie from T.D. to 3", and capped with asphalt patch.				
Used 15.3 cu.ft. of cement.				

RECEIVED 02 SEP 20 AM 11:02 STATE ENGINEERS OFFICE

Date started 9/12/2002, 19__
Date completed 9/12/2002, 19__

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 60 Feet Depth Cased 59.5 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10	Inches	0	Feet	60	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4.5	2.41	Sch. 40	0	59.5

Perforations:
Type perforation Slot
Size perforation 0.020"
From 29.5 feet to 59.5 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 25'
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 25 feet to 59.5 feet

9. WATER LEVEL
Static water level 47.5 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Lang Exploratory Drilling (Contractor)
Address P.O. Box 5279 (Contractor)
Elko, NV 89802-5279
Nevada contractor's license number issued by the State Contractor's Board 0021976
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2115
Signed Dustin Wilcaf (By driller performing actual drilling on-site or contractor)
Date 9/17/02

USE ADDITIONAL SHEETS IF NECESSARY

B.STL