



PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 50424

1. OWNER GEORGE & MERRIE BENESCH ADDRESS AT WELL LOCATION 3630 La May Lane
 MAILING ADDRESS 3600 La May Lane Reno, Nevada 89511
 2. LOCATION NW 1/4 SW 1/4 Sec. 12 T. 18N N/S R 19 E Washoe County
 PERMIT NO. 230-091-02 South West Reno Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top soil		0	1	1
Brown clay, boulders & gravel		1	17	16
Purple volcanic boulder		17	22	5
Brown sandy clays with boulders & gravel		22	28	6
Brown cemented sands & gravels		28	39	11
Brown sandy clays, some gravels		39	63	24
Brown sandy clays		63	144	81
Soft zone		144	146	2
Light brown volcanic sandy clays		146	154	8
Gray volcanic rock		154	174	20
Soft zone		174	176	2
Gray volcanic rock		176	235	59
Purple volcanic rock		235	310	75
Fracture(NO WATER)		310	312	2
Purple & gray volcanic rock		312	330	18
Fracture	X?	330	331	1
Gray volcanic rock		331	345	14
Fracture volcanic rock	X?	345	363	18
Gray volcanic rock		363	381	18
Soft zone		381	382	1
Gray volcanic rock		382	400	18

10-1-02 At depth of 400 ft. GPM was 4-5 GPM
 Owner like to abandon/plugg well. Try other site.

8. WELL CONSTRUCTION
 Depth Drilled 400 Feet Depth Cased _____ Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 Inches To 100 Feet
 8 5/8 Inches 100 Feet 400 Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)

Perforations:
 Type perforation _____
 Size perforation _____
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal _____
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 165-178 feet below land surface
 Artesian flow _____ G.P.M. 4-5 P.S.I.
 Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name WAYNE DRILLING, INC. Contractor
 Address P.O. BOX 12370 Contractor
RENO, NEVADA 89510
 Nevada contractor's license number 0022549 issued by the State Contractor's Board
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923
 Signed [Signature] driller performing actual drilling on site or contractor
 Date October 7, 2002

7. WELL TEST DATA
 TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
4-5		

10-2-02 Run tremie pipe to bottom. Rig grout pump & lines. Mix & pump 81 sacks cement with high pressure. 10-3-02 Cement @86 ft. Back fill to 20 ft. with clean dirt. Fill with 20 ft. of cement. 88 sacks cement total used.