WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 87919
Permit No.
Basin 101

NOTICE OF INTENT NO. 48276

1. OWNER Frank Woolsey
MAILING ADDRESS 2161 W Williams Ave PMB 280
Fallon, NV 89406

ADDRESS AT WELL LOCATION 1274 Robin Drive,
Fallon, NV 89406

2. LOCATION NW 1/4 SE 1/4 Sec. 21 T 19N N/S R 28E E Churchill County
PERMIT NO. Issued by Water Resources | 008-282-48 Parcel No. | Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown Sand		0	9	9
Brown Clay		9	20	11
Brown Sand		20	34	14
Brown Clay		34	37	3
Gray Clay		37	42	5
Gray Sand		42	55	13
Gray Clay		55	58	3
Brownish Sand		58	60	2
Gray Clay		60	61	1
Brown Sand	XX	61	64	3

Date started 09/09/2002, 19__
Date completed 09/09/2002, 19__

RECEIVED 02 SEP 27 AM 11:12 STATE ENGINEER'S OFFICE

7. WELL TEST DATA

TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20		1hr

8. WELL CONSTRUCTION
Depth Drilled 64 Feet Depth Cased 64 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10	Inches	0	Feet	64	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	0	10
6 PVC	3.92	.258	10	64

Perforations:
Type perforation Saw Cut
Size perforation 1/8
From 61 feet to 64 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 55
Placement Method: [X] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout
Gravel Packed: [X] Yes [ ] No
From 55 feet to 64 feet

9. WATER LEVEL
Static water level 20 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cool °F Quality unknown

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Parsons Drilling, Inc. (Contractor)
Address P.O. Box 1265 (Contractor)
Fallon Nv. 89407-1265
Nevada contractor's license number issued by the State Contractor's Board 29064
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2212
Signed Wayne Brown (By driller performing actual drilling on-site or contractor)
Date 09/10/2002

USE ADDITIONAL SHEETS IF NECESSARY