WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 87929
Permit No.
Basin 191

NOTICE OF INTENT NO. 46964

1. OWNER ALEJANDRO PENA
MAILING ADDRESS P.O. BOX 3409
WEST WENDOVER, NV 89833

ADDRESS AT WELL LOCATION SW CORNER OF G ST & 2ND

2. LOCATION NE 1/4 NW 1/4 Sec. 11 T 37N N/S R 69E E ELKO County
PERMIT NO. (Issued by Water Resources) | 011-001-040 (Parcel No.) | CLOVER ACRES (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SANDY SOIL		0	2	2
BROWN CLAY		2	40	38
SILTSTONE & CLAY		40	100	60
SILTSTONE	110	100	130	30

RECEIVED 02 MAY -9 AM10:30 STATE ENGINEER'S OFFICE

Date started 3/15/2002 , 19__
Date completed 3/18/2002 , 19__

7. WELL TEST DATA

TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
25		3.5

8. WELL CONSTRUCTION
Depth Drilled 130 Feet Depth Cased 130 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 5/8 Inches		0 Feet	130 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
65/8	13	.188	+1	130

Perforations:
Type perforation MILLSLOT
Size perforation 3/16 X 3
From 120 feet to 130 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [X] Pumped [ ] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 130 feet

9. WATER LEVEL
Static water level 35 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature C °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name HACKWORTH DRILLING, INC. (Contractor)
Address P.O. BOX 850 (Contractor)
ELKO, NV 89803
Nevada contractor's license number issued by the State Contractor's Board 020582
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1689
Signed [signature] (By driller performing actual drilling on-site or contractor)
Date 3/25/2002

USE ADDITIONAL SHEETS IF NECESSARY