WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 87934
Permit No.
Basin 089

NOTICE OF INTENT NO. 38670

1. OWNER Mark Ashworth
MAILING ADDRESS 3390 Lyon LN.
Washoe Valley, NV

ADDRESS AT WELL LOCATION
3390 Lyon LN.
Washoe Valley, NV

2. LOCATION ~~NW~~ SE ¼ ~~SE~~ NW ¼ Sec. 6 T 16 N/S R 20 E Washoe County

PERMIT NO. N/A (Issued by Water Resources) | 050-442-02 (Parcel No.) | Subdivision Name

3. WORK PERFORMED
☐ New Well ☒ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown Sandy Clay		0	3	
Brown Sand		3	32	
Green Sandy Clay		32	34	
Green Sand		34	67	
Gray Clay		67	93	
Gray Sand		93	121	
Very Course Sand		121	140	
White Sand and				
Gray Clay		140	172	
Gray Clay		172	194	
Green Clay w/Black				
Rock ledge		194	210	
[illegible]te Sand		210	220	

Date started 7-23-02, 19
Date completed 7-27-02, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Approx	50	200	5 hrs.

8. WELL CONSTRUCTION
Depth Drilled 220 Feet Depth Cased 220 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12¼"	Inches	0 Feet	10 Feet
9 7/8	Inches	10 Feet	220 Feet
	Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	+2	8
6 5/8	4.95	.390	+2	220

Perforations:
Type perforation Mill Slot
Size perforation .010"
From 120 feet to 140 feet
From 200 feet to 220 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 100+
Placement Method: ☒ Pumped ☐ Poured

Seal Type:
☒ Neat Cement
☐ Cement Grout
☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 100 feet to 220 feet

9. WATER LEVEL
Static water level 20 feet below land surface
Artesian flow none G.P.M. none P.S.I.
Water temperature cool °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name MILLER & SONS DRILLING COMPANY (Contractor)
Address P.O. Box 8056 (Contractor)
Reno, NV 89507

Nevada contractor's license number issued by the State Contractor's Board 37915
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1418

Signed Bruce Mueller
By driller performing actual drilling on site or contractor
Date 8-25-02

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627