

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 01931
 Permit No. 67904
 Basin 033A

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

Page 1 of 2

NOTICE OF INTENT NO. 50391

Reconditioned by NIS #50391

1. OWNER **Bob Dexter**
 MAILING ADDRESS **P.O. Box 175**
Orovada, NV 89445

ADDRESS AT WELL LOCATION
41.627804 N
117.827559 W NAD 22 RP

2. LOCATION NE 1/4 NE 1/4 Sec. 8 T 43N N/S R 37E E Humboldt County
 PERMIT NO. 67904
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
sand clay		0	25	
sand		25	26	1
gravel		26	35	9
clay & sand		35	38	3
gravel		38	50	12
sandy gravel w/clay		50	60	10
clay		60	62	2
sandy gravel		62	70	8
sand/clay		70	75	5
sandy gravel		75	85	10
clay		85	90	5
gravel/sand		90	95	5
sand		95	98	3
gravel		98	104	6
sandy clay		104	109	5
gravel		109	119	10
clay/sand		119	123	4
sand		123	146	23
clay/sand		146	149	3
gravel/cobbles	x	149	156	7
cobbles	x	156	162	6
sandy gravel	x	162	173	11
sandy clay		173	197	24
gravel	x	197	211	14
coarse sand/pea gravel	x	211	221	10
clay		221	233	12

Continued on next page

8. WELL CONSTRUCTION
 Depth Drilled 610 Feet Depth Cased 600 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
36 Inches 0 Feet 50 Feet
26 Inches 50 Feet 610 Feet
 Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>30</u>		<u>conductor</u>	<u>0</u>	<u>50</u>
<u>18</u>		<u>.321</u>	<u>0</u>	<u>600</u>

Perforations:
 Type perforation Quad row mill slot
 Size perforation 1/8 x 3
 From 140 feet to 600 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 0 feet to 600 feet

9. WATER LEVEL
 Static water level 79.75 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cool °F Quality good

Date started 4/22/02, 19____
 Date completed 4/24/02, 19____

7. WELL TEST DATA

TEST METHOD:	TEST METHOD:		
	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input checked="" type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
P/L 123	4200	43.25	8 Hrs.

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name **Humboldt Drilling & Pump Co., Inc.** Contractor
 Address **4675 W. Winnemucca Blvd** Contractor
Winnemucca, Nevada 89445
 Nevada contractor's license number issued by the State Contractor's Board 015234
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1154-T1
 Signed Tom A. Long
 By driller performing actual drilling on-site or contractor
 Date 5/3/02

* See Reconditioning Log # 110153