WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.3[illegible]

OFFICE USE ONLY
Log No. 87939
Permit No.
Basin 129

NOTICE OF INTENT NO. 47385

1. OWNER Tim Whitaker
MAILING ADDRESS 4105 Unionville Rd.
Unionville, NV 89418

ADDRESS AT WELL LOCATION 4105 Unionville Rd

2. LOCATION NE 1/4 NE 1/4 Sec. 27 T 30N N/S R 34E E Pershing County
PERMIT NO. _____ Issued by Water Resources | 012-020-06 Parcel No. | Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
cobbles & clay		0	30	
fractured brown rock		30	60	30
gray rock w/fractures		60	150	90

Date started 2/25/02, 19__
Date completed 2/28/02, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
30		3 hrs.

8. WELL CONSTRUCTION
Depth Drilled 150 Feet Depth Cased ~~100~~ 150 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12-1/4 Inches		0 Feet	100 Feet
9-7/8 Inches		100 Feet	150 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6-5/8		.188	+2	110

Perforations:
Type perforation mill slot
Size perforation .90 x 3
From 110 feet to 150 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 100
Placement Method: [X] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 100 feet to 150 feet

9. WATER LEVEL
Static water level 6 feet below land surface
Artesian flow ____ G.P.M. ____ P.S.I.
Water temperature cool °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Humboldt Drilling & Pump Co., Inc. (Contractor)
Address 4675 W. Winnemucca Blvd (Contractor)
Winnemucca, Nevada 89445

Nevada contractor's license number issued by the State Contractor's Board 015234

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1713

Signed [signature] (By driller performing actual drilling on-site or contractor)

Date 3/8/02