MW2-8

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 87948
Permit No.
Basin 072

NOTICE OF INTENT NO. 43497

1. OWNER FLORIDA CANYON MINING, INC.
MAILING ADDRESS P.O. BOX 907
IMLAY, NV 89418

ADDRESS AT WELL LOCATION
STANDARD MINE AREA

2. LOCATION NE ¼ SE ¼ Sec. 35 T 31 N N/S R 33 E PERSHING County
PERMIT NO. M/O 1229 B (Issued by Water Resources) Parcel No. Subdivision Name

3. WORK PERFORMED
[XX] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [XX] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [XX] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Silicified Siltstone		0	20	20
Silicified Limestone		20	30	10
Gray Limestone		30	150	120
Void		150	170	20
Gray Limestone		170	370	200
Dark Gray Limestone		370	600	230
Water Level: 390 feet below surface.				
plugged by log 11/7/90				

RECEIVED 02 AUG 22 AM 11:08 WATER RESOURCES OFFICE

Date started July 28, 2002, ~~19~~
Date completed July 29, 2002, ~~19~~

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 600 Feet Depth Cased 600 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
5 3/4 Inches	0 Feet	600 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2	PVC	Sch.80	+2	600

Perforations:
Type perforation Mill slot PVC
Size perforation .020
From 100 feet to 600 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [XX] Yes [ ] No
Depth of Seal 50
Placement Method: [XX] Pumped [ ] Poured
Seal Type: [XX] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [XX] Yes [ ] No
From 100 feet to 600 feet

9. WATER LEVEL
Static water level 390 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name GEORGE DELONG CONSTRUCTION, INC. (Contractor)
Address P.O. BOX 907 WINNEMUCCA, NV 89446 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 0002120C
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 8-2-02
Signed (Driller performing actual drilling on site or contractor)
Date 01375

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627