WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 87965
Permit No.
Basin 105

NOTICE OF INTENT NO. 50607

1. OWNER Jeffery Pisciotta Builders
MAILING ADDRESS P.O. Box 336
Gardnerville, NV 89410

ADDRESS AT WELL LOCATION 973 Heavenly View Court
Gardnerville, NV. 89410

2. LOCATION NE NW 1/4 ~~NW~~ NE 1/4 Sec. 17 T 12N N/S R 20E E Douglas County
PERMIT NO. Issued by Water Resources
1220-17-501-022 Parcel No.
Heavenley View Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [X] Other mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
	no			
Clay soil smal	no	0		
boulders			3	3
unsorted sand and	no	3		
gravel			17	14
Course DG	no	17	39	22
well sorted smal	yes	39		
gravel and sand			87	48
pea gravel and sand	yes	87	140	53

RECEIVED
02 AUG -7 AM 11:30
STATE ENGINEERS OFFICE

Date started 8/1/2002, 19__
Date completed 8/3/~~1~~902 20, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
30		1 hr.

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 5/8	Inches	0	Feet	140	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13	.188	+2	140

Perforations:
Type perforation Factory Milled
Size perforation 3/16 X 3 6 Row
From 120 feet to 140 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [X] Pumped [ ] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 140 feet

9. WATER LEVEL
Static water level 35 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Eddco Exploration Inc. Contractor
Address 7780 Curry Road Contractor
Fallon, NV. 89406
Nevada contractor's license number issued by the State Contractor's Board 27673A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1586
Signed [signature] By driller performing actual drilling on-site or contractor
Date 8/4/2002

USE ADDITIONAL SHEETS IF NECESSARY