WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 88010
Permit No.
Basin 212

NOTICE OF INTENT NO. 24299

1. OWNER: RUFFIN GAMING LLC
MAILING ADDRESS: 3120 S. LAS VEGAS BLVD.
LAS VEGAS, NV 89109

ADDRESS AT WELL LOCATION: FRONTIER HOTEL & CASINO
3120 S. LAS VEGAS BLVD.
LAS VEGAS, NV 89109

2. LOCATION: SE ¼ SW ¼ Sec. 9 T. 21 N/S R. 61 E. CLARK County
PERMIT NO. (Issued by Water Resources) | Parcel No. 162-16-101-002 | Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☒ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☒ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Wire brush entire well | 0 | 541 | 541 | |
| Original well O.D. 12" | | | | |
| Install 10" liner with 304 ss | | | | |
| screen. | | | | |
| Install new 40hp sub pump & | | | | |
| motor. | | | | |

Date started 11/14/02, 20
Date complated 1/10/03, 20

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| | | |

8. WELL CONSTRUCTION
Depth Drilled Feet Depth Cased Feet

HOLE DIAMETER (BIT SIZE)

| | From | To |
|---|---|---|
| Inches | Feet | Feet |
| Inches | Feet | Feet |
| Inches | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 12 | 33.38 | .250 | | |
| | | | | |
| | | | | |

Perforations:
Type perforation: ss screen
Size perforation: .010 screen opening
From 300 feet to 520 feet
From 400 feet to 440 feet
From 340 feet to 360 feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☐ No
Depth of Seal
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☐ No
From feet to feet

9. WATER LEVEL
Static water level 101 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name ALLEN DRILLING INC. (Contractor)
Address 4015 West Tompkins (Contractor)
Las Vegas, NV 89103

Nevada contractor's license number issued by the State Contractor's Board 18917

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1301

Signed (By driller performing actual drilling on site or contractor)

Date

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627