WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 88018
Permit No.
Basin 101

NOTICE OF INTENT NO. 47493

1. OWNER Bob Hammon
MAILING ADDRESS 5075 Alcorn Road
Fallon, NV 89406

ADDRESS AT WELL LOCATION GOlden Circle, Fallon, NV 89406

2. LOCATION NW 1/4 NW 1/4 Sec. 28 T 19N N/S R 28E E Churchill County
PERMIT NO. 65100 (Issued by Water Resources) 008-472-06 (Parcel No.) Subdivision Name

3. **WORK PERFORMED**
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. **PROPOSED USE**
[ ] Domestic [ ] Irrigation [ ] Test
[X] Municipal/Industrial [ ] Monitor [ ] Stock

5. **WELL TYPE**
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. **LITHOLOGIC LOG**

Material	Water Strata	From	To	Thickness
Brown Sand		0	7	7
Brown Clay		7	25	18
brown Sand		25	34	9
Brown clay		34	36	2
Brown Sand		36	45	9
Gray Clay		45	53	8
Black Sand		53	60	7
Gray Sand		60	69	9
Brown Sand		69	95	26
Gray Clay		95	97	2
Gray Sand		97	110	13
Gray Clay		110	131	21
Gray Sand		131	142	11
Brown Clay		142	143	1
Brown Sand	XX	143	155	12

Date started 09/27/2001, 19__
Date completed 09/27/2001, 19__

7. **WELL TEST DATA**
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. **WELL CONSTRUCTION**
Depth Drilled 155 Feet Depth Cased 155 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10	Inches	0	Feet	155	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	0	10
6 PVC	3.92	.258	10	155

Perforations:
Type perforation Saw Cut
Size perforation 1/8
From 152 feet to 155 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 100
Placement Method: [X] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 100 feet to 155 feet

9. **WATER LEVEL**
Static water level 9 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cool °F Quality unknown

10. **DRILLER'S CERTIFICATION**
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Parsons Drilling, Inc. (Contractor)
Address P.O. Box 1264 (Contractor)
Fallon Nv. 89407
Nevada contractor's license number issued by the State Contractor's Board 29064
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1753-T1
Signed [signature] (By driller performing actual drilling on-site or contractor)
Date 09/28/2001

USE ADDITIONAL SHEETS IF NECESSARY