

New APN 1022-18-001-048

WHITE-DIVISION OF WATER RESOURCES
CANARY-CLIENT'S COPY
PINK-WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY

Log No. 88052

Permit No. 106

Basin

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 45435

1. OWNER: Daniel F Sullivan ADDRESS AT WELL LOCATION: No Address
 MAILING ADDRESS: P.O. Box 1577 Location Corner of Highway 395 S
Gardnerville Nev. 89410 + 208 W south of Gardnerville
 2. LOCATION: SE 1/4 NE 1/4 Sec. 13 T. 10 N/S R. 22E Douglas County
 PERMIT NO. 56925 37-123-08 None
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED: New Well Replace Recondition Deepen Abandon Other

4. PROPOSED USE: Domestic Irrigation Test Municipal/Industrial Monitor Stock

5. WELL TYPE: Cable Rotary RVC Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>alluvial top soil + small rocks</u>		<u>0</u>	<u>60</u>	<u>60</u>
<u>gravel</u>	<input checked="" type="checkbox"/>	<u>60</u>	<u>70</u>	<u>10</u>
<u>brown clay</u>		<u>70</u>	<u>100</u>	<u>30</u>
<u>sand</u>	<input checked="" type="checkbox"/>	<u>100</u>	<u>120</u>	<u>20</u>
<u>sandy clay</u>		<u>120</u>	<u>133</u>	<u>13</u>
<u>sand</u>	<input checked="" type="checkbox"/>	<u>133</u>	<u>150</u>	<u>17</u>
<u>sandy clay</u>		<u>150</u>	<u>165</u>	<u>15</u>
<u>sand + small gravel mix</u>		<u>165</u>	<u>190</u>	<u>25</u>

8. WELL CONSTRUCTION
 Depth Drilled 190 Feet Depth Cased 190 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From	To
<u>10</u>	<u>0</u>	<u>58</u>
<u>6</u>	<u>50</u>	<u>190</u>

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6</u>		<u>180</u>	<u>0</u>	<u>190</u>

Perforations:
 Type perforation: factory saw slot
 Size perforation: 3/32 N.B.
 From 60 feet to 70 feet
 From 150 feet to 190 feet

Surface Seal: Yes No Seal Type: Neat Cement Cement Grout Concrete Grout
 Depth of Seal: 60
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level: 0 feet below land surface
 Artesian flow: 25 G.P.M. 25 P.S.I.
 Water temperature: Cold °F Quality: good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name: Edmund Miller Drilling Contractor
 Address: P.O. Box 92 Smith Nev 89430 Contractor
 Nevada contractor's license number: 32166 A
 issued by the State Contractor's Board
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller: 718
 Signed: Edmund Miller
 By driller performing actual drilling on site or contractor
 Date: April 5 - 02

Date started: March 25 02
 Date completed: April 23 02

7. WELL TEST DATA

TEST METHOD: Bailor Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>60</u>	<u>8 ft</u>	<u>24</u>

RECEIVED
CRAP I AM: 07
WATER RESOURCES OFFICE

APR 23 2002
11:29 AM