WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 88067
Permit No.
Basin 137-B

NOTICE OF INTENT NO. 50584

1. OWNER Carrie Miller
MAILING ADDRESS HC65 Box 196
Austin, NV 89310-9100

ADDRESS AT WELL LOCATION Smokey Valley, NV

2. LOCATION SE 1/4 SE 1/4 Sec. 10 T 14N N/S R 43E E churchill County
PERMIT NO. Issued by Water Resources | Parcel No. | Subdivision Name

3. **WORK PERFORMED**
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. **PROPOSED USE**
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. **WELL TYPE**
[ ] Cable [ ] Rotary [ ] RVC
[X] Air [ ] Other

6. **LITHOLOGIC LOG**

Material	Water Strata	From	To	Thickness
Top Soil		0	2	2
Brown CLay		2	10	8
Gray Sand & Gray Clay		10	25	15
Brown Sand & Brown		25		
Clay			57	32
Brown Clay & Gravel		57	70	13
Brown Clay & Sand		70	109	39
Brown Clay		109	125	16
Brown Sand & Gravel		125	132	7
Brown Sand & Brown		132		
Clay			165	33
Brown Sand	XX	165	175	10
Brown Clay		175	185	10

Date started 10/28/2002 , 19__
Date completed 10/30/2002 , 19__

7. **WELL TEST DATA**
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
150		1hr

8. **WELL CONSTRUCTION**
Depth Drilled 185 Feet Depth Cased 185 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
14	Inches	0	Feet	185	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	14.96	.188	0	185

Perforations:
Type perforation Mill CUt
Size perforation 1/8
From 150 feet to 175 feet
From 110 feet to 130 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [X] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout
Gravel Packed: [X] Yes [ ] No
From 50 feet to 185 feet

9. **WATER LEVEL**
Static water level 0 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cool °F Quality unknown

10. **DRILLER'S CERTIFICATION**
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Parsons Drilling, Inc. Contractor
Address P.O. Box 1265 Contractor
Fallon Nv. 89407-1265
Nevada contractor's license number issued by the State Contractor's Board 29064
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2212
Signed [signature] By driller performing actual drilling on-site or contractor
Date 10/31/2002

USE ADDITIONAL SHEETS IF NECESSARY