WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 88068
Permit No.
Basin 059

NOTICE OF INTENT NO. 43262

1. OWNER Alfonso + Shannon Ramirez
MAILING ADDRESS 1089 2100 EAST Battle Mountain, NV 89820
ADDRESS AT WELL LOCATION 1089 2100 EAST Battle Mountain 89820

2. LOCATION NW ¼ SE ¼ Sec. 28 T. 32 N/S R. 45 E. Lander County
PERMIT NO. Domestic (Issued by Water Resources) | 11230 (Parcel No.) | None (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Topsoil		0	5	5
Sand		5	40	35
Clay Blue		40	50	10
Sand		50	70	30
Blue Clay		70	80	10
Sand + Fine Gravel		80	105	25
Blue Clay		105	113	8

Weird address but I don't think the street the Battle Mountain is Battle Mountain that's the name of the town

Date started 6-20 2002
Date completed 6-21 2002

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
W.C.R.	25	UNKNOWN	5

8. WELL CONSTRUCTION
Depth Drilled 113 Feet Depth Cased 113 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From Feet	To Feet
10 5/8	+0	113

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	10	188	+1	113

Perforations:
Type perforation Factory Cut
Size perforation 3/32x4
From 93 feet to 113 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 113 feet

9. WATER LEVEL
Static water level 30 feet below land surface
Artesian flow N/A G.P.M. N/A P.S.I.
Water temperature Cool °F Quality Fair

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Fred Anderson Drilling (Contractor)
Address 10760 Grass Valley Rd (Contractor)
Winn NV 89445
Nevada contractor's license number issued by the State Contractor's Board 021467
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2083
Signed (By driller performing actual drilling on site or contractor)
Date 6-24-02

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627