

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 50903

1. OWNER Donna Carson ADDRESS AT WELL LOCATION 1692 Hyde St. MINDEN NV
 MAILING ADDRESS 1692 Hyde St. MINDEN NV 89423
 2. LOCATION N2 1/4 NW 1/4 Sec 2 T 13 S R 20 E Douglas County
 PERMIT NO. 1320-02-001-111 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
CLAYEY SAND		248	280	
SAND with CLAY lenses w/ small gravel		280	305	
CLAYEY SAND		305	325	
		325	344	
Black, Reddish BROWN Rock				

8. WELL CONSTRUCTION
 Depth Drilled 344 Feet Depth Cased 344 Feet
 HOLE DIAMETER (BIT SIZE)
 From 7 7/8 Inches 248 Feet To 344 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>		<u>.188</u>	<u>234</u>	<u>284</u>
<u>6 5/8</u>		<u>.188</u>	<u>304</u>	<u>324</u>

Perforations:
 Type perforation factory slot
 Size perforation 1 1/16 x 3"
 From 284 feet to 304 feet
 From 324 feet to 344 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal _____
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 208.5 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature COOL °F Quality _____

Date started 7-8-02, 19_____
 Date completed 7-11-02, 19_____
 7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>20-25</u>		<u>2 hours</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Sierra Nevada Drilling + Pump LLC Contractor
 Address 3540 Green Acres Dr. Carson City, NV 89705
 Nevada contractor's license number 52078 issued by the State Contractor's Board
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1902
 Signed John L. Smith driller performing actual drilling on site or contractor
 Date 7-11-02