

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 57952

1. OWNER Sterling Ranch Estates LLC ADDRESS AT WELL LOCATION North at intersection of  
 MAILING ADDRESS PO Box 41 Geneva NV 89411 Property + 30 Lane GARONVILLE NV

2. LOCATION SE 1/4 SE 1/4 Sec. 1 T. 12 N. S. R. 20 E Douglas County  
 PERMIT NO. 1200-01-002-003 Sterling Ranch Estates Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SAND + Gravel		0	60	60
Clayey gravel		70	90	20
SANDY gravel	X	90	180	90
clayey gravel		180	190	10
gravel + SAND	X	190	210	20
clayey gravel		210	220	10
gravel + SAND	X	220	240	20

8. WELL CONSTRUCTION  
 Depth Drilled 240 Feet Depth Cased 240 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 10 5/8 Inches To 240 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>		<u>.188</u>	<u>+1</u>	<u>160</u>

Perforations:  
 Type perforation factory slot  
 Size perforation 1 1/16 x 3"  
 From 160 feet to 240 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 50 feet to 240 feet

9. WATER LEVEL  
 Static water level 110 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature cool °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Sierra Nevada Drilling & Pump LLC Contractor  
 Address 3540 Green Acres Dr. Carson City NV 89705 Contractor  
 Nevada contractor's license number 52078 issued by the State Contractor's Board  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1902  
 Signed John Bohach  
 By driller performing actual drilling on site or contractor  
 Date 7-1-02

Date started 6-20-02, 19\_\_\_\_\_  
 Date completed 6-30-02, 19\_\_\_\_\_

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>65+</u>		<u>2 hours</u>

RECEIVED  
 02 JUL 16 AM 10:56  
 STATE ENGINEERS OFFICE