WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 88087
Permit No. ~~11499~~ 51749
Basin

NOTICE OF INTENT NO. 23755

1. OWNER Simplot
MAILING ADDRESS PO Box 308
Overton, Nv. 89040

ADDRESS AT WELL LOCATION

2. LOCATION NW ¼ NE ¼ Sec. 11 T. 17 N/S R. 67 E. Clark County
PERMIT NO. ~~11499~~ 51749 (Issued by Water Resources) ~~071-30-301-002~~ (Parcel No.) 079-00-001-014 (Subdivision Name)

3. WORK PERFORMED
☐ New Well ☑ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☑ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sandstone - Orange		0	13	13
Sandstone - off white		13	57	44
Sandstone - yellow		57	140	83
Sandstone - off white		140	335	195
Sandstone - white, grey	X	335	480	145
Sandstone - Grey	X	480	540	60
Mudstone - Grey, black		540	820	280

DCNR/DWR Received MAR 19 2003 LAS VEGAS OFFICE

2003 MAR 21 AM 10:16 WATER ENGINEERING OFFICE

Date started June 25, 2002
Date completed Dec. 18, 2002

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☑ Pump ☑ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
July 28	250		6 hrs
Aug. 15	140	Air Vac	500 hrs
Sept. 20	225	63'	30 hrs

8. WELL CONSTRUCTION
Depth Drilled 820 Feet Depth Cased 820 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
19 Inches		0 Feet	50 Feet
12¼ Inches		50 Feet	820 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
14	36.71	.250	0	50
8 5/8	22.36	.250	+2	820

Perforations:
Type perforation Factory mill
Size perforation 1/8 x 2 1/2
From 420 feet to 600 feet
From 640 feet to 680 feet
From 740 feet to 820 feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 50'
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☑ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 0 feet to 820 feet

9. WATER LEVEL
Static water level 224' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature 74 °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Webber Drilling Contractor
Address 2475 W. 3935 S. Contractor
West Valley City, Ut. 84119
Nevada contractor's license number issued by the State Contractor's Board 0025887
Nevada driller's license number issued by the Division of Water Resources, the onsite driller 1557
Signed By driller performing actual drilling on site or contractor
Date Dec. 20, 2002

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(01)-627