WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 88088
Permit No.
Basin 110C
NOTICE OF INTENT NO. 46483

1. OWNER Hawthorne Army Depot
MAILING ADDRESS 1 South Maine Ave
Hawthorne, NV 89415-9662

ADDRESS AT WELL LOCATION
Western Area Demilitarization Facility
WDF-20

2. LOCATION NE ¼ NW ¼ Sec. 32 T. 09 N/S R. 30 E. Mineral County
PERMIT NO. (issued by Water Resources) Parcel No. Lat. 38°35' 48.86" Long. 118°39' 39.00" Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other HS Auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand and Gravel, Silt	x	0	24	24
Clay and Silt		24.0	24.5	0.5

Date started 21 March 2002
Date completed 21 March 2002

7. WELL TEST DATA
TEST METHOD: ☒ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

STATE ENGINEERS OFFICE
02 APR 24 AM 11:11
RECEIVED

8. WELL CONSTRUCTION
Depth Drilled Feet Depth Cased Feet

HOLE DIAMETER (BIT SIZE)

	From	To
6 Inches	Feet	Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2.5				

Perforations:
Type perforation Factory Cut Slots in PVC (Sch 40)
Size perforation .010 inch
From 13.34 feet to 23.34 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From feet to feet

9. WATER LEVEL
Static water level 15.68 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature 17.7 °C Quality 3371 µmhos/cm

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name USACHPPM (Contractor)
Address 5158 Blackhawk Rd / MCHB-TS-EGW (Contractor)
Aberdeen Proving Ground, MD 21010
Nevada contractor's license number — issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site driller NGWA 195435
Signed Mark E. Tarr (By driller performing actual drilling on site or contractor)
Date 4/15/02

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627