

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

**WELL DRILLER'S REPORT**  
Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 47964

1. OWNER Carson City Wash water ADDRESS AT WELL LOCATION Stewart Pond  
MAILING ADDRESS 3326 E. 5th ST  
CARSON CITY, NV

2. LOCATION NW 1/4 NW 1/4 Sec 4 T 14 S R. 20 E Carson City County  
PERMIT NO. MB-1242 09-311-40 Parcel No. Stewart Pond Carson City Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other Auger

6. LITHOLOGIC LOG

| Material   | Water Strata | From | To | Thickness |
|--|--------------|------|----|-----------|
| Medium sand, brown<br>some rock                      |              | 0    | 5  | 5'        |
| Loam some clay<br>black                              |              | 5    | 10 | 5'        |
| Sand, some rocks,<br>little clay, brown<br>and moist |              | 10   | 15 | 5'        |
| Sand, very clean,<br>brown                           | X            | 15   | 24 | 9'        |

8. WELL CONSTRUCTION

Depth Drilled 24 Feet Depth Cased 24 Feet

HOLE DIAMETER (BIT SIZE)

| From                | To                           |
|---------------------|------------------------------|
| <u>6 5/8</u> Inches | <u>0</u> Feet <u>24</u> Feet |
| <u>2</u> Inches     | Feet Feet                    |
| Inches              | Feet Feet                    |

CASING SCHEDULE

| Size O.D. (Inches)            | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|-------------------------------|---------------------|-------------------------|-------------|-----------|
| <u>2</u>                      | <u>PVC</u>          | <u>Sch 40</u>           | <u>0</u>    | <u>24</u> |
| <u>ASTM 480 Flush threads</u> |                     |                         |             |           |

Perforations:

Type perforation Factory slot  
Size perforation 0.02 inch

From 14 feet to 24 feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
Depth of Seal 6.5 to 3 feet  Neat Cement  
Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
From 13 feet to 24 feet

Date started August 14 2002  
Date completed August 14 2002

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

| G.P.M.              | Draw Down (Feet Below Static) | Time (Hours) |
|---------------------|-------------------------------|--------------|
| <u>GPS Location</u> | <u>NAD 27</u>                 |              |
| <u>39° 6'</u>       | <u>38.5"</u>                  |              |
| <u>119° 45'</u>     | <u>2.9"</u>                   |              |

9. WATER LEVEL

Static water level 14.2 feet below land surface  
Artesian flow No G.P.M. \_\_\_\_\_ P.S.I. \_\_\_\_\_  
Water temperature \_\_\_\_\_ °F Quality unknown


10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name R.N. Pennington Contractor  
Address 333 W. 7th Ln Contractor  
Carson City NV 89706



Nevada contractor's license number issued by the State Contractor's Board \_\_\_\_\_  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller FP1857

Signed R.N. Pennington  
By driller performing actual drilling on site or contractor  
Date 8-15-02



Stewart

Stewart



40 Feet Approx.

Bigelow St.

8-14-02