

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 47951  
 ADDRESS AT WELL LOCATION DIRECTLY EAST OF E. VALLEY  
Ro. 3500' +/- North of JO LANE  
GARONVILLE, NV

1. OWNER Sterling Ranch Estates LLC ADDRESS AT WELL LOCATION DIRECTLY EAST OF E. VALLEY  
 MAILING ADDRESS P.O. BOX 41 GENOA, NV 89411 Ro. 3500' +/- North of JO LANE  
GARONVILLE, NV

2. LOCATION NW NW Sec. 1 T. 12 S. R. 20 E. Douglas County  
 PERMIT NO. 68504-T 1220-01-002002 Sterling Ranch Estates  
Issued by Water Resources Parcel No. Division Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal  QUI  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>SAND + Gravel</u>		<u>0</u>	<u>70</u>	<u>70</u>
<u>very Clayey gravel</u>		<u>70</u>	<u>80</u>	<u>10</u>
<u>gravel w/ a little clay</u>		<u>80</u>	<u>100</u>	<u>20</u>
<u>SANDY gravel</u>	<u>X</u>	<u>100</u>	<u>170</u>	<u>70</u>
<u>very clayey gravel</u>		<u>170</u>	<u>185</u>	<u>15</u>
<u>SANDY gravel</u>	<u>X</u>	<u>185</u>	<u>205</u>	<u>20</u>
<u>Clayey gravel</u>		<u>205</u>	<u>210</u>	<u>5</u>
<u>gravel w/ sand clay</u>	<u>X</u>	<u>210</u>	<u>220</u>	<u>10</u>
		<u>220</u>	<u>225</u>	<u>5</u>

8. WELL CONSTRUCTION  
 Depth Drilled 225 Feet Depth Cased 225 Feet

HOLE DIAMETER (BIT SIZE)  
 From 105/8 Inches To 0 Feet 225 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>65/8</u>		<u>.188</u>	<u>+1</u>	<u>185</u>

Perforations:  
 Type perforation Factory Slot  
 Size perforation 1/16 x 3/16  
 From 185 feet to 225 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
 From 50 feet to 225 feet

9. WATER LEVEL  
 Static water level 108 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature COOL °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Sierra Nevada Drilling + Pump LLC Contractor  
 Address 3540 Green Acres Dr Contractor  
Carson City NV 89705  
 Nevada contractor's license number issued by the State Contractor's Board 52078  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1902  
 Signed John B. Reisch  
 By driller performing actual drilling on site or contractor  
 Date 7-1-02

Date started 6-14-02, 19\_\_\_\_  
 Date completed 6-19-02, 19\_\_\_\_

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailor <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>50+</u>		<u>2 HOURS</u>

RECEIVED  
 02 JUL 16 AM 10:56  
 STATE ENGINEERS OFFICE