WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 88144
Permit No.
Basin 109

NOTICE OF INTENT NO. 48255

1. OWNER Bryan L. Masini
MAILING ADDRESS Sweetwater, NV
ADDRESS AT WELL LOCATION Hwy 338 Sweetwater, NV

2. LOCATION NW ¼ NW ¼ Sec. 16 T. 7 N/S R. 25 E Lyon County
PERMIT NO. 14495 Cert. 4153 (Issued by Water Resources) | Parcel No. | Sweetwater Ranch Co (Subdivision Name)

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☒ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clean out well to 297 feet By air drilling and foam. Mixed and pumped Abentonite from 297 feet back to surface. 9.1 lbs. weight. Set Rubber Packer at 20' feet then pumped Neat Cement 15.9 lbs to surface. Note Tony Eng from Water Resources was present during plugging Hole.				

Date started Sept 9/02, 19
Date completed Sept 11/02, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
water level was 15 feet when we started. after cleaning hole out water level droped to 50 feet.		

8. WELL CONSTRUCTION
Depth Drilled 297 Feet Depth Cased 297' Feet

HOLE DIAMETER (BIT SIZE)

	From	To
Inches	Feet	Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Diam. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
10 3/4		.188	0	297

Perforations:
Type perforation Sawed
Size perforation 1/8 X 3
From feet to feet
From feet to feet
From Surface feet to ? Bottom feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☒ No
Depth of Seal
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☐ No
From unknown feet to feet

9. WATER LEVEL
Static water level 15 - 50 feet feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Leach Drilling Inc (Contractor)
Address PO Box 599 (Contractor)
Silver Springs NV 89429
Nevada contractor's license number issued by the State Contractor's Board 0031841
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1740
Signed Nathaniel L. Leach (By driller performing actual drilling on site or contractor)
Date Oct 6/02

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627